


# BMID Turbidity February 2020

(Single Point Daily Sampling with Inline Hach 1720c)



	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	AVG
Distribution Intake	0.47	0.49	0.51	0.52	0.52	0.51	0.48	0.53	0.54	0.50	0.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.50
Booster#1- First User	0.44	0.43	0.42	0.43	0.44	0.48	0.42	0.38	0.44	0.41	0.43	0.51	0.08	0.05	0.06	0.07	0.06	0.06	0.07	0.07	0.05	0.02	0.04	0.01	0.03	0.02	0.05	0.05	0.22
Mission Creek Intake	2.83	1.45	0.98	0.70	0.79	0.73	0.64	0.62	0.60	0.82	0.80	0.72	0.60	0.65	0.68	0.63	0.62	0.65	0.70	0.77	0.85	0.87	0.68	0.73	0.66	0.96	0.82	0.81	0.66

Date