

Approved Date: April 3, 2023

The **Approved Products List** (APL) provides a list of approved products that can be installed on City of Kelowna owned infrastructure. Any use of an alternate product requires the approval of the APL Committee.

The following products have been reviewed and are approved in accordance with the **Approved Products** List - Administrative Policy.

#### 1. Water Distribution

- 1.1. Watermain and Service Pipe
- 1.2. Fittings and Appurtenances
- 1.3. Valves
- 1.4. Hydrants and Hydrant Paint
- 1.5. Brass Service Fitting
- 1.6. Kiosks

### 2. Sanitary Sewer

- 2.1. Sanitary Mains and Services
- 2.2. Fittings and Appurtenances
- 2.3. Manholes
- 2.4. Pressure Systems

### 3. Stormwater

- 3.1. Storm Mains and Services
- 3.2. Fittings and Appurtenances
- 3.3. Manholes and Drywells
- 3.4. Containment Devices and Oil-Grit Separators

### 4. Highway

- 4.1. Traffic Signs
- 4.2. Traffic Painting

### 5. Roadway Lighting

- 5.1. Luminaires
- 5.2. Photocell
- 5.3. Poles
- 5.4. Bases
- 5.5. Electrical Service Disconnect

### 6. Traffic Signals

### 7. Landscape and Irrigation

- 7.1. Controller
- 7.2. Fittings and Appurtenances



Date Section Material Manufacturer Make/Model Size Range Comments/Conditions Approved mm/yyyy 1 Water Distribution Products must conform to CSA Standard, where applicable. All bolts to be stainless steel or high-strength low-alloy steel bolts. All bolts & unprotected metallic fittings to be protected with petrolatum primer and tape. Chipped or damaged epoxy coated fittings must be repaired as per manufactured specifications All PVC Watermains to be pigmented Blue 1.1 Watermain and Service Pipe IPEX PVC DR 18, PR235 PVC 100 to 900mm AWWA C900 Royal Only if approved by the City Engineer. Not to be used for pump PVC DR 25, PR165 IPEX mains or where there might PVC AWWA C900 350 to 1500mm be frequent transient Royal pressure fluctuations, or where potential pressure zone changes could occur. Only if approved by City Engineer. Soil conditions must be investigated to determine need for cathodic protection. Must be Canada Pipe installed with Polyethylene **Ductile Iron** Ductile C151 400mm and up. US Pipe encasement per manufacturer regardless of soil conditions. (See Bylaw 7900 Water Design section) Pipe to be cement mortar lined to AWWA C-104. Watermain HDPE



Date Section Material Manufacturer Make/Model Size Range Comments/Conditions Approved mm/yyyy min. 19mm 3/4") Service Pipe Great Lakes Must conform to CSA Type k Copper HC.7.6 & ASTM B88 Copper max. 50mm (2") Only Series 160 or 200 conforming to CAN/CSA-B137.1-M.Due to its thicker min. 25mm (1") wall, all plastic pipe's IPEX Polyethylene ID are smaller than max. 50mm (2") copper; confirm flow capacity. Add trace wire for plastic service pipe. Due to its thicker wall, all plastic pipe's ID are smaller than min. 25mm (1") copper; confirm flow Rehau MUNICIPEX\* max. 50mm (2") capacity. Add trace wire for plastic service pipe. 1.2 Fittings and Appurtenances Refer to Section 2.3 for Manhole products C900 / 905 / 907. Pressure IPEX PVC 5 degree CIOD All Sizes Watermain Class to meet or exceed Fittings - PVC bend mainline. C900 / 905 / 907. Pressure Galaxy Plastics PVC 5 degree CIOD All Sizes Class to meet or exceed Ltd bend mainline. C900 / 905 / 907. Pressure PVC 5 degree CIOD All Sizes Class to meet or exceed Pro-Line Fittings bend

PVC 5 degree CIOD

bend

Royal

All Sizes

mainline.

mainline.

C900 / 905 / 907. Pressure

Class to meet or exceed



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
	Watermain Fittings – Ductile Iron	TC / ACS	Ductile Iron	100 – 600 mm	C-153 Fittings only	
		Sigma	Ductile Iron	100 – 600 mm	C-153 Fittings only	
		Corporation	Ductile Iron	100 – 600 mm	C-153 Fittings only	
	Anti-corrosion Petrolatum Products	Petro Coating Systems Ltd.	Paste & primer, Mastic, Tape		See City of Kelowna Standard Drawings.	
		Denso North America	Denso Paste, LT tape		See City of Kelowna Standard Drawings.	
	Restraining Joints				Restraining Joints are not to be used on AC or CI Watermain.	
		Ford Meter Box Co. / Uni-Flange	UFR1300C UFR1350C UFR1390C UFR1309-C UFR1399-C	100 – 600 mm 100 – 600 mm 100 – 600 mm 100 – 450 mm 100 – 450 mm		
		Smith Blair	115 165 136 (PVC Fittings)	100 – 600 mm 100 – 600 mm 100 – 200 mm		
		Sigma	PV – LOC Series Zip Flange	100 – 600 mm 100 – 600 mm	PV-LOC is directional only for PVC. Install according to manufacturer instructions. Zip Flange is a flange adaptor for DI pipe.	
		EBAA Iron	Series 1500 PVC Series 2800 Series 1900 Series 2946	100 – 300 mm 350 – 600 mm 100 – 300 mm 400mm	Series 1500 is only for C900 (i.e., 100-300mm)	



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
		IPEX	Polyethylene	min. 25mm (1") max. 50mm (2")	Only Series 160 or 200 conforming to CAN/CSA-B137.1-M.Due to its thicker wall, all plastic pipe's ID are smaller than copper; confirm flow capacity. Add trace wire for plastic service pipe.	
		Rehau	MUNICIPEX*	min. 25mm (1") max. 50mm (2")	Due to its thicker wall, all plastic pipe's ID are smaller than copper; confirm flow capacity. Add trace wire for plastic service pipe.	
	Service Saddles			19 – 50mm		
		Robar	2616 2626 2706	50 – 300 mm 100 – 450 mm 100 – 600 mm	Dbl-bolt Dbl-strap with stainless steel straps	
		Canada Pipe	SC-2	100 – 400 mm	With stainless steel straps	
		Ford	FS313 202 BS	100 – 300mm 100 – 762 mm	With stainless steel straps	
		Cambridge Brass	812 8403 8407	100 – 300 mm 100 – 300 mm 300mm & larger	Two-piece – 4 bolts Single piece – 2 bolts Two-piece – 4 bolts	
	Service Tapping Saddles			100mm & larger		
		Robar	All	100mm & larger	Manufactured steel for metal pipe only.	
		Smith-Blair	All	100mm & larger	Manufactured steel for metal pipe only.	
		JCM	All	100mm & larger	Manufactured steel for metal pipe only.	
		Robar	All	100mm & larger	Stainless steel for all pipe types.	



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
		Smith-Blair	All	100mm & larger	Stainless steel for all pipe types.	
		Smith-Blair	All	100mm & larger	Stainless steel for all pipe types.	
	Couplings				All couplings to be Fusion Bonded Epoxy Coated Ductile Iron	
		Ford	FCA-ESH FC2W Ultra	100 – 300 mm 100 – 600 mm 100 – 300 mm		
		Robar	Vantage	100 – 600 mm 100 – 300 mm 100 – 200mm		
		Smith Blair		100-400 mm 100-300mm		
		Viking Johnson	Maxi-Fit & Maxi-Step	All sizes		
		Romac	XR 501 Extended Range	100 – 300 mm	All Romac to be epoxy coated	
			PVC Repair & High Deflection Couplings	All sizes	C900 / 905 / 907. Pressure class To meet or exceed mainline.	
					c/w Stainless Steel Rods & SS-RHD or MD-RHD Clevis Ends.	
	Service Valve Boxes	Meuller	A-726 A-728	20 – 25 mm 37 – 50 mm	Nelson Valve Box with Water Lid. Riser pipe to be notched out an mounted over service and supported by precast concrete patio block. Or as required by ID.	



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy		
					c/w Stainless Steel Rods & SS-RHD or MD-RHD Clevis Ends.			
		Trojan Industries	VSB1 VSB2	20 – 25 mm 37– 50 mm	Nelson Valve Box with Water Lid. Riser pipe to be notched out an mounted over service and supported by precast concrete patio block. Or as required by ID.			
	Main Valve Boxes	TC / ACS	MR-6	Minimum 375mm	Nelson Type Lid			
		Dobney Foundry Armtec	MR-6		Nelson Type Lid			
	Valves							
	Valves Gate Valves – Resilient Wedge							
	Mueller	A-2362	50 – 100 mm	250 PSI				
		Mueller	A-2361	100 - 1370 mm	250 PSI – DI			
			3100 PO x PO	100 – 300mm	250 PSI – DI			
			3200 PO x FL	100 – 300mm				
		TC / ACS	3300 MJ × MJ	100 – 300mm				
		IC/ACS	3400 MJ x FL	100 – 300mm				
			3500 FL x FL	50mm – 300mm				
			3700 Thrd x Thrd	50mm – 75mm				
	Valves	Butterfly Valves		·				
					All design recommendations to be approved by the City Engineer. Installation requires placement within chamber for access and maintenance.			
	Air Valves	Vent-O-Mat	RBX					



Approved Date: April 3, 2023 Date Section Material Manufacturer Make/Model Size Range Comments/Conditions Approved mm/yyyy 1.4 Hydrants Hydrants TCH1A only c/w Storz Terminal City C-71-P Fitting Canada Valve Mueller-Century c/w Storz Fitting DULUX PAINTS (High gloss, lead free enamel. **Hydrant Paint** Self-priming with rust inhibitor) METALCLAD 218419 P-1 RED STOCK COLOUR METALCLAD 218412 P-2 BLUE STOCK COLOUR 218413 METALCLAD P-3 YELLOW FFR1Y32 METALCLAD 218414 P-4 GREEN STOCK COLOUR METALCLAD 218427 P-5 ORANGE STOCK COLOUR METALCLAD 218420 P-6 BLACK STOCK COLOUR 1.5 **Brass Service Fittings** BrassService Fittings No Lead Brass Corporation Stops Mueller B-25008 20 – 50 mm Full port only A.Y. McDonald 74701BQ 20 – 50 mm Full port only Ford FB 1000 20 – 50 mm Full port only Full port c/w new mueller Cambridge Brass Series 301

20 – 50 mm

gasket



<u>Appro</u>	ved Products Li	ist - Administrati	ve Policy		Approved Date: April	3, 2023
Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
	Curb Stops				Stop & Drains NOT permitted	
		Mueller	B-25209	20 – 50 mm	Full port only	
		A.Y. McDonald	76100Q	20 – 50 mm	Full port only	
		Ford	B44 Series	20 – 50 mm	Only full port models 333,444, 555, 666 & 777	
	Service Line Couplers	Ford	C44 Series	20 – 50 mm	Models C44-1 to C44-88	
		Mueller	H-15403	20 – 50 mm	H15403, H15404 & H12940	
		Cambridge Brass	Series 118 & 119	20 – 50 mm		
1.6	Kiosks					
	Pressure Reducing Stations	Valid Manufacturing	KXXA89-150-47-01	89"Hx150"Wx47D	Quad Door Kiosk with end Cabinet	
	Air Valve	Valid Manufacturing	HRV344227-170165	25-100mm	Inulated heated enclosure where above ground air valves are utilized.	
2	Sanitary Sewer					
		roved by the City I	•	,	oe 50) or alternate cement e iron components shall be	
2.1	Pipe Mains and	Services				
		IPEX "Ring-Tite" Royal "Flex-Lox"	PVC DR35	For 200mm diameter and up.	Must meet CSA B182.2 Gasket joint.	



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
		IPEX "Ring-Tite" Rehau "BondLoc" Royal "Flex-Lox"	PVC DR28	100 – 150mm (All Makes)	Must meet CSA B182.2 Gasket joint	
		IPEX "Blue Brute" Royal "FlexLox"	Pressure Pipe for Sewer Forcemains	100 – 300mm 350 – 900mm	Colour to be White with "SEWER FORCEMAIN" Printed on it. Must meet CSA B137.3, C900, Class 235 (DR 18), gasket joint.	
		Langley Ocean Pipe A.E. Concrete Armtec	Reinforced Concrete	300 – 3000mm	Concrete pipe must meet CSA A257 Series-14, C 789M-95a specification for Precast Reinforced Concrete Pipe. Sulphate resistant ASTM E 632.	
2.2	Fittings and App	urtenances				
	Couplings	IPEX Royal Galaxy Plastics Ltd. Mission Rubber (Flex-Seal)	Corebell Adaptor	100 – 675mm 100 – 675mm 100 & up	Must not be plasticized PVC. Shear band and clamps to be 316 Series stainless steel. Clamps must be nut & bolt design. Bushings to be integral.	
	Inserted Service Connections	Galaxy Plastics Ltd. Inserta Fittings Co. Royal	EZ Tee Inserta Tee Fat Boy, PVC gasket type	100mm	May be used on existing mains 200mm & larger or on new mains 375mm & larger	
		Galaxy Plastics Ltd. Inserta Fittings	EZ Tee Inserta Tee Fat Boy, PVC gasket type	150mm	Refer to STD DWG SS-50 for Manhole requirement. May be used on existing mains 300mm & larger or new mains 375mm & larger	
		Inserta Fittings	EZ Tee Inserta Tee Fat Boy, PVC gasket type	200mm	Manhole required on services 200mm and up. Special Approval required for existing mains 300mm & larger or new mains 375mm & larger	



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
	Inspection Chambers	Royal Galaxy Plastics	Sewer Gasketed Fittings	100 – 200mm	Single service IC's only. With provision for "add-a- flap" check valve (PICF04*SS).	
	Inspection Chamber Caps & Lids	Royal Galaxy Plastics	191-LL (Red/Green)	200mm	PVC. Must be locking type. Red in colour for sanitary sewer	
	Service Boxes		WM-37-1 No. 1480	590 x 410mm 545 x 370mm	Brooks style box. State "Sanitary" or "Storm" on cover.	
	45 Degree Wye	Royal IPEX Galaxy Plastics Ltd.	Services	All	PVC gasket type. No wye saddles allowed.	
	Service Bends	Royal Galaxy Plastics Ltd.	Service sweep Fittings	All	Long radius sweeps only. PVC Gasketed. PVC Gasketed Sewer Fittings	
	Gaskets	IPEX Rehau Royal	"Ring-tite" PVC "BondLoc" PVC "Flex-Lox" PVC	200 – 1200mm		
2.3	Manholes					
	Manhole Frame & Cover			762mm (30 in)	Refer to Supplementary Standard Detail Drawings for required lettering on manhole covers. Refer to installation specifications.	
	Manhole Grade Rings	Langley Concrete	720 – 723 MH-6 915	50 - 150mm	760mm diameter opening 760mm, 565 Sloped rings	
	IMailliole Dailei	Kon Kast Langley Concrete	Concrete	1050 – 2400mm	Refer to Standard Detail Drawings	
	Manhole Rungs		Aluminum		Refer to Standard Detail Drawings	
	IMailliole Dailei	Kon Kast Langley Concrete	Concrete	1050 – 2400mm	Refer to Standard Detail Drawings 760mm diameter opening	



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy	
	Manhole Barrel Bases	Kon Kast Langley Concrete	Concrete	1050 – 2400mm	Refer to Standard Detail Drawings		
	Flow Control	Galaxy Plastics Ltd.	Inlet Control Device	100mm & larger	For use in Flow Control Manholes Debris Screens		
	Internal Drops	Royal Reliner/Duran	PVC A-4 A-6 B-8 B-10	100 - 200mm 100mm 150mm 200mm 250mm	Refer to Standard Detail Drawings Inside drop bowl.		
2.4	Pressure System	ns	1				
3	Stormwater						
3.1	Pipe Mains and S	Services					
	Pipe mains	IPEX "Ultra Rib" Royal "Kor Flo"	Ribbed PVC	200 – 600mm	Must meet CSA B182.4 Concentric ribbed pipe only is accepted. (storm only). No spiral ribbed pipe.		
		(as above)	Perforated PVC	200 – 600mm	With perforations as per Standard Drawing SS-S53		
3.2	Fittings and App	purtenances					
	Refer to Section 2.2 for Fittings and Appurtenances products unless otherwise listed below.						
	Inspection Chamber Caps & Lids	Royal Galaxy Plastics	191-LL (Red/Green)	200mm	PVC. Must be locking type. Green in colour for storm drainage		



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
	Culverts	Armtec Atlantic Industries	Non-reinforced Concrete Reinforced Concrete Reinforced Concrete Arch Reinforced Concrete Box Corrugated Steel Multi-Plate BOSS 2000 HDPE Ribbed	See manufacturer spec's	Concrete pipe must meet CSA A257 Series-14. Soils testing required for suitability when specifying metal pipe. C 789M-95a Specification for Precast Reinforced Concrete Box Sections for Culverts, Storm Drains, and Sewers. C 850M-95b Specification for Precast reinforced concrete Box Sections for culverts, Storm Drains and Sewers with less than 0.6 m of cover subjected to Highway Loadings. Note: Corrugated steel pipe (CSP) limited to driveway and road crossings only. Not to be used contiguous with collection pipe networks.	
	Headwall	· ·	Pre-cast concrete headwalls		Grills required for 450mm and larger and pipes longer than 30m	
	Headwall Inlet	Kon Kast	Inlet structure with grillage Model 1487		Grills required for 450mm and larger pipes longer than 30m.	
	Catch Basin Rollover Frame and Grate	Westview Dobney Foundry Ltd. Terminal City Ironworks Trojan Industries	RB7 frame & grate B-39M – modified grate T-K7	632mm (~25in)	Specified by design engineer where location of driveway letdowns are unknown.	
	Catch Basin Combined Side & Gutter Inlet	Westview Sales Ltd. TC/ACS Dobney & Trojan	with side inlet	627mm (~25in)	To be used with standard barrier curb or as specified by design engineer.	



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy		
3.3	Manholes and Di	ywells						
	Refer to Section 2.3 for Manhole products unless otherwise listed below.							
	Containment De	vices and Oil/Grit	Sonarators					
3.4			·					
			nvironmental Technology \nts for water quality to rece		nadian ETV) and have sufficient			
		Armtec	Pro-Eco-Lite Headwalls	300mm – 2000mm				
			Swirl-type oil/water separator <sup>1</sup>					
		Armtec Hydro- Brake	Vortex flow control		Alternate to orifice control. Must be engineered and design verified by Armtec.			
			Swirl-type oil/water separator <sup>1</sup>					
		Contech CON/SPAN	Concrete Detention & Infiltration		Large volume underground detention. Open bottom optional for infiltration.			
			Swirl-type oil/water separator <sup>1</sup>					
		Infiltrator Water Technologies	Infiltrator systems		Where infiltration is recommended.			
		PolyDrain - Interceptor A-67	Drain systems		Interceptor trench drains.			



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
		Management	Enhanced trapping hood system for gravity separation.		Installed in minimm 1050mm manhole barrel to replace standard catch basin. Use of these devices to be limited to intersections and not used as primary outfall treatment device.	
		Stormtech Chambers	Chamber / Infiltrator			
4	Highway					
4.1	Traffic Signs					
	Sign-Street Name					
	Sign-Traffic					
	Sign Bases					
	Sign Posts					
	Sign Fasteners					
4.2	Pavement Markii	ngs				
	Thermal Plastics					
	Paint					
5	Roadway Ligh	ting				



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
5.1	Luminaires		1			
	LED Cobra Lumi	naires				
	Cobra		31W_ERL1_0_04_B3_30 31W_ERL1_0_04_C3_30		31W, LED, 4000 Lumens, Type II Wide, 3000K 120V- 277V, ANSI C136.41 7 Pin, Gray, IP66, Tool-less Entry, Optional Secondary Enhanced Surge Protection	
	Cobra		39W_ERL1_0_05_B3_30 39W_ERL1_0_05_C3_30		39W, LED, 5000 Lumens, Type II Wide, 3000K 120V- 277V, ANSI C136.41, 7 Pin, Gray, IP66, Tool-less Entry, Optional SecondaryEnhanced Surge Protection	
	Cobra	GE GE	47W_ERL1_0_06_B3_30 47W_ERL1_0_06_C3_30		47W, LED, 6000 Lumens, Type II Wide, 3000K 120V- 277V, ANSI C136.41, 7 Pin, Gray, IP66, Tool-less Entry, Optional Secondary Enhanced Surge Protection	
	Cobra	GE GE	71W_ERL1_0_08_B3_30. 71W_ERL1_0_08_C3_30.		71W, LED, 8000 Lumens, Type II Wide, 3000K 120V- 277V, ANSI C136.41, 7 Pin, Gray, IP66, Tool-less Entry, Optional Secondary Enhanced Surge Protection	
	Cobra		82W_ERL1_0_10_B3_30 82W_ERL1_0_10_C3_30		82W, LED, 10000 Lumens, Type II Wide, 3000K 120V- 277V, ANSI C136.41, 7 Pin, Gray, IP66, Tool-less Entry, Optional Secondary Enhanced Surge Protection	
	Cobra	GE GE	136W_ERL1_0_15_B3_3( 136W_ERL1_0_15_C3_3(		136W, LED,15000 Lumens, Type II Wide, 3000K 120V- 277V, ANSI C136.41, 7 Pin, Gray, IP66, Tool-less Entry, Optional Secondary Enhanced Surge Protection	



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
	LED Decorative	Luminaires				
	Post Top	Phillips Phillips	PDP10050W64LED3KMF UNIVRCD7MGY PDP10050W64LED3KMF UNIVRCD7MGY		Post Top, LED 4000 Lumens, Type II 3000 K 120-277V, Flat glass dimmable, UL/CSA listed, 10 KV/KA surge protection, Gray, 7 pin photoeye receptical, meets ANSI C136.31, UL8750, UL1598, B2-U2-G1	
	Decorative Post Top	King Luminaire	K123R-B2AR-II-50(SSL)-: 277-3K-HSS-K14	1042-120:	WELLINGTON STYLE Luminaire, LED,4000 Lumens, Type II Wide, 3000K 120V-277V, with Photoeye receptical and side shield	
	Decorative Post Top	King Luminaire	K425R-T1AR-II-50(SSL)- 277-3K-HSS-K14	4004-120:	ACCORN STYLE Luminaire, LED,4000 Lumens, Type II Wide, 3000K 120V-277V, with Photoeye receptical and side shield	
	Decorative Pendant	King Luminaire	47W_ERL1_0_06_B3_30.	A_GRAY_ILR	AURORA SAG STYLE Luminaire , LED,4000 Lumens, Type II Wide, 3000K 120V-277V, with Photoeye receptical and side shield, c/w Plumbizer	
	Decorative Pendant	King Luminaire	47W_ERL1_0_06_C3_30.	A_GRAY_ILR	HARBOUR STYLE Luminaire , LED,4000 Lumens, Type II Wide, 3000K 120V-277V, with Photoeye receptical and side shield, c/w Plumbizer	
5.2	Photocell					
		INTERMATIC	LED4536SC		LOCKING TYPE 120-277 Volt	
5.3	Poles		•		•	
	Galvanized Powder Coated Green Poles					



## <u>Approved Products List - Administrative Policy</u> <u>Approved Date: April 3, 2023</u>

Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
	Davit	Nova Pole, Valmont	122-30-A2206A-F5 10020-07		22x6 Single Davit, C/W 10"- 11" BCD, Galv. & Powder Coated Green	.,,,,
	Davit	Nova Pole, Valmont	122-30-A3008A-F5 10170-07		30x8 Single Davit, C/W 10"- 11" BCD, Galv. & Powder Coated Green	
	Double Davit	Nova Pole, Valmont	102-75-60202C-F5		Type 2C Double Davit Arm, Type 1 Flange Galv. & Powder Coated Green	
	Double Davit Pole	Nova Pole, Valmont			Type 2 Shaft, 6.5 m, Type 1 Flange, Galv. & Powder Coated Green	
	Post Top	Nova Pole, Valmont			6 metre Galv. & Powder Coated Green	
	Post Top	Nova Pole, Valmont			7.5 metre Galv. & Powder Coated Green	
	Decorative Powo	der Coated Black	Poles			
	Decorative Base	Nova Pole, Valmont			Henderson With Transition adapter Powder Coated Black	
5.4	Bases					
	Decorative Base					
		Nova Pole, Valmont			Henderson With Transition adapter Powder Coated Black	
	Service Bases					
		Nova Pole	Open Top Service Base	NTB36 Open Top	Open top service base for use with Davit and Post Top poles. Powder Coated Kelowna Green	
		Nova Pole	Closed Top Service Base	NTB36 Closed Top	Closed top service base for use as a remote service with any pole style. Powder coated Kelowna Green for davit and post top poles and powder coated Black for decorative pole locations	



Approved	Date:	Aprii	ა,	2023
• •		•		

Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy			
5.5	Electrical Service Disconnect								
		Valid Manufacturing	BSDA6A18		Base Service Disconnect				
6	Traffic Signals	1	,	,					
7	Landscape and	d Irrigation							
7.1	Controller								
	Controller	Toro	Sentinel V3		Configured to communicate with Sentinel Central Control c/w level 3 surge protection				
		Rain Bird	ESP LXMEF		Configured to communicate with Rain Bird IQ Central Control				
		Rain Bird	ESP LXD		For decoder systems; configured to communicate with Rain Bird IQ Central Control				
		Manufacturing	Dwg# KSDA48-36-16- 02	48"Hx36"Wx16"D W/MW and lockable handles					
	Controller Kiosk Base	Leko Precast Ltd.			Per Detail Drawing				
7.2	Fittings and Ap	purtenances							
	Backflow Prevention Assembly - DCVA	Apollo	4A-100 Series	Up to 2"					
		Apollo	4A-100 Series	2 1/2" or greater					



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
		Watts	Series 709w/NRS	2 1/2" or greater		
	Pressure Regulating Valve	Watts	LF25 AUB-DU-Z3	Up to 2" , lead free, double union		
		Watts	Watts PV 10M	Greater than 2"		
	Hydrometer	Hydrometer (1.5")	Netafim	LHM15EM11AAFMEL	ER register preprogrammed. Output: gal/pulse red: 0.1 green: 1.0 Instructions: wire controller to red wire only. Decoder systems require manufacturer's decoder cable. Other systems require PE39 cable	
		Hydrometer (2")	Netafim	LHM2EM11AAFMEL	ER register preprogrammed. Output: gal/pulse red: 0.1 green: 1.0 Instructions: wire controller to red wire only. Decoder systems require manufacturer's decoder cable. Other systems require PE39 cable	
		Hydrometer (3")	Netafim		ER register preprogrammed. Output: gal/pulse red: 0.1 green: 1.0 Instructions: wire controller to red wire only. Decoder systems require manufacturer's decoder cable. Other systems require PE39 cable	
	Electrical Control Valve	Hunter	ICV			
		Rain Bird	PEB			



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
		Toro	P-220			
	Low Flow Control Valve	Hunter	ICV			
		Rain Bird	PEB			
		Toro	TPV			
	Low Flow Filter	Rain Bird	ОКСНК			
		Rain Bird	PRB-QKCHK			
	High Flow Filter	Amiad	Amiad 1.5" Super		Installed as per Detail Drawings.	
	Air Relief Valve	Rain Bird	ARV050	0.5" air relief valve		
		Rain Bird	Air/Vacuum Relief Valve	0.75" air relief valve w/ compression tee and flush cap		
		Toro	T-YD-500-34	0.5" air relief valve		
	Isolation Valve	Red & White	206	Up to 2"		
		Clow	w/flanged ends	3"		
		Clow	Resilient Wedge Gate Valve Model C515 w/flanged ends	4" or greater		
	Quick Coupler Valve	Rain Bird	5-RC			



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
	Sprinklers - Sprayhead	Hunter	PRO-SPRAY PRS30			
		Hunter	PRO-SPRAY PRS40			
		Rain Bird	PRS-SAM Series			
		Toro	PRX-COM Series			
	Sprinklers - Rotor	Hunter	PGJ			
		Hunter	I-20			
		Hunter	I-25			
		Hunter	I-40			
		Rain Bird	3500 SAM			
		Rain Bird	5000 PL SAM PRS			
	Sprinklers - Rotor	Rain Bird	5500			
		Rain Bird	6504			
		Rain Bird	8005			
		Toro	Mini 8			
		Toro	Т5			
		Toro	Т7			



Section	Material	Manufacturer	Make/Model	Size Range	Comments/Conditions	Date Approved mm/yyyy
	Drip Emitter / Bubblers	Hunter series			Installed as per Detail Drawings.	
		Rain Bird series			Installed as per Detail Drawings.	
		Toro series			Installed as per Detail Drawings.	
	Sub-surface Dripline	Hunter	PLD			
		Rain Bird	XFS			
		Toro	DL2000 Series			
		Netafim	Techline HCVXR			
	Root Zone Watering System	Hunter	RZWS		w/ root watering sock	
		Rain Bird	RWS Series		w/ root watering sock	
	Valve Box / Extensions	Carson Industries	LLC Specification Grade		Locking lid w/stainless steel bolt and washer	
		NDS Manufacturing	Pro Series			
		Rain Bird	VB-SPR (Super Jumbo Valve Box)		for Auto Flush Filter	
	Meter Vault	Kon Kast	1102			
	Meter Vault Lid	Kon Kast	1102B			
	Irrigation Vault	Kon Kast	1102			
	IrrigationVault Base	Kon Kast	1102B			



HDPE

UL, ULC, CSA

Date Section Comments/Conditions Material Manufacturer Make/Model Size Range Approved mm/yyyy Irrigation Vault c/w locking hinge for Excel Metal Fab 3974-2 Lid support when open Irrigation Vault Kon Kast 1132 c/w Base Irrigation Vault Excel Metal Fab 11040-4 3974-2 Lid VPSS-1 - with s/s pipe Specify pipe size and Vault support clamp and 1/8 rubber Excel Metal Fab adjustment length when iack ordering liner Vault sealant to be utilized around vault Dow Great Stuff Pro foam openings Locking lid w/stainless steel Wire Splice Box Carson LLC Specification Grade bolt and washer. Grey in Industries color Locking lid w/stainless steel NDS Pro Series bolt and washer. Grey in Manufacturing color Pipe PVC CSA HDPE UL, ULC, CSA PΕ UL, ULC, CSA Fittings PVC CSA