

Black Mountain Irrigation District Turbidity Monitoring

BMID Turbidity August 2017

(Single Point Daily Sampling with Inline Hach 1720c)

WQA

1.00

0.75

0.50

0.25

0.00

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Intake	0.32	0.23	0.29	0.33	0.34	0.36	0.41	0.42	0.46	0.41	0.38	0.33	0.30	0.30	0.31	0.27	0.29	0.27	0.25	0.25	0.25	0.25	0.28	0.24	0.23	0.26	0.25	0.24	0.23	0.25	0.24
Booster#1- First User	0.28	0.27	0.27	0.36	0.40	0.43	0.45	0.50	0.51	0.52	0.44	0.39	0.35	0.36	0.38	0.37	0.35	0.32	0.33	0.32	0.34	0.32	0.31	0.30	0.30	0.31	0.32	0.29	0.29	0.30	0.23

— Intake — Booster#1- First User