



MONTHLY REPORTING PERIOD - MAY, 2018

1. SUMMARY

The list below provides a summary of the water quality information collected by BMID in May, 2018. Documentation and figures are provided on the following pages to support this submission.

| Source | May 2018 | |
|--------------------------------|-----------------|---------------------|
| | Total (US Gals) | Total (Mega Litres) |
| Mission Creek | 444,059,000 | 1,680.76 |
| Well 4 | 0 | 0 |
| Well 5 | 21,529,000 | 81.49 |
| Scotty Creek (Irrigation Only) | 894,100 | 3.38 |
| Total | 466,482,100 | 1,765.63 |

1. A malfunctioning valve, used to regulate the flow between Stevens and Hadden Reservoirs, required repairs in late May. As a result, BMID was forced to utilize Hadden Reservoir's Mission Creek intake as the primary supply source for the distribution system;
2. The Water Treatment Plant was turned off and Stevens Reservoir was drained beginning May 23, 2018, to facilitate the required valve repair at Stevens Reservoir outlet;
3. Due to poor water quality in Mission Creek entering directly into Hadden Reservoir, BMID was forced to issue a Boil Water Notice beginning May 23, and lasting throughout the rest of May 2018;
4. Turbidity levels at the Distribution Intake remained below 1.0 NTU from May 1 to May 23, 2018. Beginning on May 24, turbidity increased as a result of raw water reaching Hadden Reservoir outlet. Peak turbidity at the Distribution Intake was 12.48 NTU on May 27, 2018;
5. The highest monthly turbidity level recorded at the first customer (Booster #1) was 13.20 NTU on May 27, 2018 during the BWN;
6. Mission Creek experienced extremely high flows as the mid to lower elevations of the watershed continued melting resulting on several high-flow events and isolated flooding;
7. BMID's Scotty Creek source, used for irrigation in the north-end, resumed operations on May 3, 2018;
8. Well #5 was used throughout May as a source for both domestic and irrigation water in the north-end of the system, in conjunction with Mission Creek system water, as determined by usage and pressures in the area;
9. *E. Coli* levels at Mission Creek's Point of Diversion were average during May. The highest raw water *E. Coli* count was 48 on May 22, 2018;

10. *E.Coli* levels at the Distribution Intake had low counts on all samples throughout early May, however the peak count of 10 occurred on May 30, 2018;
11. No *E.Coli* and no *Coliforms* were found in treated water in the distribution system through third-party analysis. In addition, no positive bacteria tests were found from the in-house presence-absence tests during routine testing;
12. A new dedicated sample station was installed in Solly Court and will be utilized for presence/absence testing;
13. BMID's Water Treatment Plant resumed normal operations on March 15, 2018. The WTP was temporarily shut down to facilitate the valve repair at Stevens Reservoir on May 23, 2018. The plant remained off-line for the remainder of the month. The WTP will remain in use throughout the spring and summer until the Mission Creek water source is of sufficient quality to by-pass treatment;

1.0 FLOWS - MAY, 2018

Maximum est. Daily Flow was on May 24, 2018 at 25,150,000 US gallons (95.19 ML)

Minimum est. Daily Flow was on May 10, 2018 at 5199,000 US gallons (19.68 ML)

Mission Creek provided 95% of domestic flow throughout May.

Figure 1.1 - Domestic Water System Flow




Table 1.2 - May, 2018 Daily Consumption Report

| Year | Mission Cr | Well #4 | Well #5 | Scotty Crk | System Total | System Total |
|--------------|-------------|---------|-------------|------------|--------------|--------------|
| 2018 | Usqpd | Usqpd | Usqpd | Usqpd | Usqpd | ML/Day |
| 1-May | 5,929,000 | 0 | 0.0 | 0 | 5,929,000 | 22.44 |
| 2-May | 7,527,000 | 0 | 0.0 | 0 | 7,527,000 | 28.49 |
| 3-May | 7,805,000 | 0 | 0.0 | 92,600 | 7,897,600 | 29.89 |
| 4-May | 8,881,000 | 0 | 0.0 | 72,500 | 8,953,500 | 33.89 |
| 5-May | 9,381,000 | 0 | 0.0 | 0 | 9,381,000 | 35.51 |
| 6-May | 11,027,000 | 0 | 732,000.0 | 0 | 11,759,000 | 44.51 |
| 7-May | 9,436,000 | 0 | 600,000.0 | 0 | 10,036,000 | 37.99 |
| 8-May | 9,929,000 | 0 | 810,000.0 | 0 | 10,739,000 | 40.65 |
| 9-May | 6,148,000 | 0 | 0.0 | 0 | 6,148,000 | 23.27 |
| 10-May | 5,199,000 | 0 | 0.0 | 0 | 5,199,000 | 19.68 |
| 11-May | 5,965,000 | 0 | 0.0 | 0 | 5,965,000 | 22.58 |
| 12-May | 7,317,000 | 0 | 0.0 | 0 | 7,317,000 | 27.69 |
| 13-May | 10,330,000 | 0 | 724,000.0 | 0 | 11,054,000 | 41.84 |
| 14-May | 14,310,000 | 0 | 975,000.0 | 0 | 15,285,000 | 57.85 |
| 15-May | 16,483,000 | 0 | 0.0 | 0 | 16,483,000 | 62.39 |
| 16-May | 17,077,000 | 0 | 0.0 | 0 | 17,077,000 | 64.64 |
| 17-May | 16,673,000 | 0 | 950,000.0 | 0 | 17,623,000 | 66.70 |
| 18-May | 15,482,000 | 0 | 721,000.0 | 0 | 16,203,000 | 61.33 |
| 19-May | 15,493,000 | 0 | 384,000.0 | 0 | 15,877,000 | 60.09 |
| 20-May | 14,603,000 | 0 | 1,433,000.0 | 0 | 16,036,000 | 60.70 |
| 21-May | 17,033,000 | 0 | 1,441,000.0 | 0 | 18,474,000 | 69.92 |
| 22-May | 18,995,000 | 0 | 1,620,000.0 | 0 | 20,615,000 | 78.03 |
| 23-May | 20,693,000 | 0 | 1,690,000.0 | 0 | 22,383,000 | 84.72 |
| 24-May | 21,874,000 | 0 | 3,276,000.0 | 0 | 25,150,000 | 95.19 |
| 25-May | 21,914,000 | 0 | 1,555,000.0 | 152,500 | 23,621,500 | 89.41 |
| 26-May | 21,342,000 | 0 | 0.0 | 112,300 | 21,454,300 | 81.20 |
| 27-May | 22,723,000 | 0 | 1,206,000.0 | 60,000 | 23,989,000 | 90.80 |
| 28-May | 22,588,000 | 0 | 1,990,000.0 | 75,200 | 24,653,200 | 93.31 |
| 29-May | 21,641,000 | 0 | 1,422,000.0 | 104,000 | 23,167,000 | 87.69 |
| 30-May | 20,199,000 | 0 | 0.0 | 160,000 | 20,359,000 | 77.06 |
| 31-May | 20,062,000 | 0 | 0.0 | 65,000 | 20,127,000 | 76.18 |
| Totals Usqpd | 444,059,000 | 0 | 21,529,000 | 894,100 | 466,482,100 | 1765.63 |
| Totals ML | 1,680.76 | 0.00 | 81.49 | 3.38 | | |
| Avg's | 14,324,484 | 54.22 | | | 15,047,810 | 56.96 |
| Max | 22,723,000 | 86.01 | | | 25,150,000 | 95.19 |
| Min | 5,199,000 | 19.68 | | | 5,199,000 | 19.68 |

2.0 RAW WATER QUALITY - BACTERIOLOGICAL MONITORING

Raw water samples were taken at three points at BMID settling ponds before chlorination

Samples were taken twice per week at the Distribution Intake's Point of Disinfection and at the Mission Creek raw water Point of Diversion; one sample is taken per week at Stevens Pond outlet (point halfway between WTP Outlet and Distribution Intake).

Samples from the previous month are also provided to show a two month trend

Figure 2.1 - E.Coli Readings (CARO Lab results) April 2018 - May 2018




Table 2.2 - E.Coli Readings (CARO Labs)

| Date | Point of Diversion E.Coli | Stevens Outlet E.Coli | Distribution Intake E.Coli |
|-----------|---------------------------|-----------------------|----------------------------|
| 1-Apr-18 | 5 | 0 | 0 |
| 4-Apr-18 | 5 | 0 | 0 |
| 11-Apr-18 | 5 | 0 | 0 |
| 16-Apr-18 | 11 | 0 | 0 |
| 18-Apr-18 | 4 | 0 | 0 |
| 20-Apr-18 | 3 | 0 | 0 |
| 25-Apr-18 | 3 | 1 | 0 |
| 30-Apr-18 | 11 | 0 | 0 |
| 4-May-18 | 8 | 1 | 1 |
| 5-May-18 | 5 | 0 | 0 |
| 9-May-18 | 15 | 0 | 0 |
| 14-May-18 | 33 | 0 | 0 |
| 16-May-18 | 1 | 0 | 1 |
| 22-May-18 | 48 | 0 | 0 |
| 24-May-18 | 2 | 1 | 0 |
| 28-May-18 | 14 | 0 | 4 |
| 30-May-18 | 14 | 0 | 10 |

Stevens or WTP Intake (Raw) - Sampling of raw water at intake from Mission Creek

Stevens Outlet (Raw) - Sampling point after exiting 142,000 m³ 1st upper balancing reservoir (Stevens Res.)

Hadden Outlet (Raw) - Sampling point after exiting 75,000 m³ 2nd lower balancing reservoir (Hadden Res.)

(Hadden Outlet = Distribution Intake - Point of Disinfection)

3.0 RAW AND TREATED WATER TURBIDITY

Turbidity for the Mission Creek source was measured at Booster Station No. 1 on Gallagher's Road, the first-customer, through May 2018. The highest turbidity recorded at this location was 13.20 NTU on May 27, 2018.

Figure 3.1 – Daily Turbidity Readings (Distribution Intake and Booster Station 1)




Table 3.2 - Daily Monitoring Record – Turbidity at Distribution Intake & Bst Stn 1

| Turbidity Point Sampling for May 2018 | | | | |
|---------------------------------------|---------------------|-------|-----------------------|-------|
| Date | Distribution Intake | | Booster#1- First User | |
| | Sample Time | [NTU] | Sample Time | [NTU] |
| 1 | 8:54 AM | 0.33 | 8:03 AM | 0.57 |
| 2 | 12:22 PM | 1.25 | 3:17 PM | 0.61 |
| 3 | 8:41 AM | 0.61 | 8:03 AM | 0.73 |
| 4 | 8:54 AM | 0.57 | 7:53 AM | 1.14 |
| 5 | 10:50 AM | 0.55 | 10:18 AM | 0.78 |
| 6 | 9:42 AM | 0.54 | 9:20 AM | 0.68 |
| 7 | 2:51 PM | 0.54 | 2:26 PM | 0.48 |
| 8 | 8:58 AM | 0.52 | 8:02 AM | 0.57 |
| 9 | 9:02 AM | 0.59 | 8:13 AM | 0.52 |
| 10 | 8:32 AM | 0.59 | 7:50 AM | 0.57 |
| 11 | 8:29 AM | 0.60 | 7:51 AM | 0.61 |
| 12 | 6:00 AM | 0.64 | 7:28 AM | 0.68 |
| 13 | 7:15 AM | 0.67 | 6:46 AM | 0.81 |
| 14 | 9:01 AM | 0.78 | 8:11 AM | 0.78 |
| 15 | 3:22 PM | 0.83 | 9:20 AM | 0.99 |
| 16 | 9:07 AM | 0.84 | 8:18 AM | 0.95 |
| 17 | 9:27 AM | 0.82 | 9:09 AM | 0.97 |
| 18 | 8:54 AM | 0.84 | 8:18 AM | 0.89 |
| 19 | 12:30 PM | 0.80 | 11:51 AM | 0.96 |
| 20 | 11:45 AM | 0.74 | 11:20 AM | 0.82 |
| 21 | 12:05 PM | 0.75 | 11:30 AM | 0.80 |
| 22 | 9:40 AM | 0.62 | 8:47 AM | 0.67 |
| 23 | 8:43 AM | 0.56 | 8:07 AM | 0.67 |
| 24 | 8:55 AM | 2.42 | 8:05 AM | 1.84 |
| 25 | 9:11 AM | 8.14 | 8:13 AM | 6.81 |
| 26 | 7:43 AM | 9.22 | 7:26 AM | 10.64 |
| 27 | 8:44 AM | 12.48 | 8:22 AM | 13.20 |
| 28 | 8:42 AM | 9.32 | 8:03 AM | 9.13 |
| 29 | 10:23 AM | 9.38 | 9:43 AM | 8.14 |
| 30 | 8:57 AM | 6.81 | 8:17 AM | 7.34 |
| 31 | 8:28 AM | 6.75 | 7:56 AM | 5.65 |
| AVG | | 2.66 | | 2.58 |

4.0 CHLORINE CONTACT TIME

Temperature, pH, current flow and chlorine residual levels are recorded to determine the CT levels that are required to provide 3 log inactivation of *Giardia*. Chlorine Contact times exceeded the CT levels required to provide 3 log (99.9%) inactivation of *Giardia Lamblia* throughout the month of May, 2018.

Figure 4.1 - CT Trending – BMID Mission Creek Source – May 2018




Table 4.2 - CT Table – Mission Creek Source

| BMID May 2018 Mission Creek Source | | | | | | | | | | | | | |
|---------------------------------------|-----------|----------|---------|----------------------|----------|-------|---------|----------------------|-----------------|---------|--------|---------|------------------------|
| DATE | pH | TEMP | PEAK | Free Cl ₂ | CT | CT | CTa/CTr | Free Cl ₂ | Cl ₂ | VOLUME | TIME | FLOW | CL ₂ DOSAGE |
| | (highest) | (lowest) | FLOW | residual | achieved | req'd | | Req'd | Dosage | TOTAL | | PRESENT | PRESENT |
| May | | [°C] | [USgpm] | [mg/L] | | | | [mg/L] | [mg/L] | [USgal] | [mins] | [USgpm] | [PPD] |
| 1 | 7.67 | 14.1 | 6255 | 1.53 | 648.1 | 115.4 | 5.61 | 0.27 | 2.0 | 2649600 | 424 | 4471 | 106 |
| 2 | 7.65 | 13.1 | 7569 | 1.38 | 483.1 | 121.0 | 3.99 | 0.35 | 3.4 | 2649600 | 350 | 5243 | 216 |
| 3 | 7.64 | 13.2 | 7158 | 1.45 | 536.7 | 120.6 | 4.45 | 0.33 | 3.1 | 2649600 | 370 | 6226 | 234 |
| 4 | 7.59 | 13.7 | 8714 | 1.52 | 462.2 | 115.3 | 4.01 | 0.38 | 3.2 | 2649600 | 304 | 7321 | 280 |
| 5 | 7.54 | 13.6 | 8075 | 1.35 | 443.0 | 112.0 | 3.95 | 0.34 | 3.3 | 2649600 | 328 | 6365 | 252 |
| 6 | 7.47 | 14.1 | 10721 | 1.50 | 370.7 | 107.2 | 3.46 | 0.43 | 3.1 | 2649600 | 247 | 6955 | 257 |
| 7 | 7.41 | 14.7 | 10132 | 1.40 | 366.1 | 99.6 | 3.68 | 0.38 | 3.1 | 2649600 | 262 | 5522 | 207 |
| 8 | 7.39 | 14.6 | 10500 | 1.46 | 368.4 | 100.2 | 3.68 | 0.40 | 3.1 | 2649600 | 252 | 6954 | 260 |
| 9 | 7.26 | 14.8 | 7115 | 1.20 | 446.9 | 91.5 | 4.89 | 0.25 | 3.4 | 2649600 | 372 | 3008 | 124 |
| 10 | 7.24 | 14.5 | 5733 | 1.02 | 471.4 | 90.5 | 5.21 | 0.20 | 3.5 | 2649600 | 462 | 2587 | 109 |
| 11 | 7.18 | 14.3 | 5916 | 1.27 | 568.8 | 92.7 | 6.14 | 0.21 | 3.6 | 2649600 | 448 | 3292 | 142 |
| 12 | 7.16 | 14.2 | 7519 | 1.26 | 444.0 | 92.5 | 4.80 | 0.26 | 3.2 | 2649600 | 352 | 5181 | 201 |
| 13 | 7.14 | 14.7 | 10468 | 1.27 | 321.5 | 88.8 | 3.62 | 0.35 | 3.2 | 2649600 | 253 | 4020 | 156 |
| 14 | 7.05 | 15.3 | 14919 | 1.42 | 252.2 | 83.7 | 3.01 | 0.47 | 3.3 | 2649600 | 178 | 9482 | 378 |
| 15 | 6.95 | 16.2 | 15565 | 1.50 | 255.3 | 76.3 | 3.35 | 0.45 | 3.2 | 2649600 | 170 | 10283 | 395 |
| 16 | 6.89 | 15.9 | 15704 | 1.48 | 249.7 | 76.0 | 3.29 | 0.45 | 3.0 | 2649600 | 169 | 10086 | 366 |
| 17 | 6.85 | 15.5 | 14149 | 1.47 | 275.3 | 76.8 | 3.58 | 0.41 | 3.1 | 2649600 | 187 | 10707 | 394 |
| 18 | 6.81 | 14.2 | 12824 | 1.40 | 289.3 | 82.1 | 3.52 | 0.40 | 3.0 | 2649600 | 207 | 11532 | 422 |
| 19 | 6.88 | 13.0 | 13265 | 1.50 | 299.6 | 92.7 | 3.23 | 0.46 | 3.0 | 2649600 | 200 | 12768 | 466 |
| 20 | 6.93 | 12.8 | 13051 | 1.59 | 322.8 | 96.7 | 3.34 | 0.48 | 3.0 | 2649600 | 203 | 9851 | 359 |
| 21 | 6.97 | 12.7 | 17866 | 1.60 | 237.3 | 99.0 | 2.40 | 0.67 | 3.1 | 2649600 | 148 | 10878 | 401 |
| 22 | 6.95 | 13.3 | 17324 | 1.71 | 261.5 | 95.2 | 2.75 | 0.62 | 2.9 | 2649600 | 153 | 12404 | 425 |
| 23 | 6.95 | 13.8 | 17345 | 1.52 | 232.2 | 90.3 | 2.57 | 0.59 | 2.8 | 2649600 | 153 | 15246 | 517 |
| 24 | 6.90 | 13.8 | 17479 | 1.75 | 265.3 | 90.5 | 2.93 | 0.60 | 3.4 | 2649600 | 152 | 14472 | 594 |
| 25 | 6.85 | 13.2 | 17666 | 1.34 | 201.0 | 88.9 | 2.26 | 0.59 | 3.6 | 2649600 | 150 | 13881 | 598 |
| 26 | 6.85 | 12.9 | 17261 | 1.36 | 208.8 | 90.9 | 2.30 | 0.59 | 3.7 | 2649600 | 154 | 13871 | 622 |
| 27 | 6.80 | 11.6 | 19905 | 1.27 | 169.1 | 96.6 | 1.75 | 0.73 | 4.2 | 2649600 | 133 | 14870 | 747 |
| 28 | 6.73 | 11.5 | 18705 | 1.12 | 158.7 | 92.8 | 1.71 | 0.66 | 5.4 | 2649600 | 142 | 16184 | 1058 |
| 29 | 6.71 | 10.7 | 17041 | 1.52 | 236.3 | 101.9 | 2.32 | 0.66 | 5.5 | 2649600 | 155 | 16083 | 1060 |
| 30 | 6.70 | 10.1 | 16545 | 1.88 | 301.1 | 109.2 | 2.76 | 0.68 | 5.0 | 2649600 | 160 | 12145 | 737 |
| 31 | 6.73 | 9.7 | 16156 | 1.74 | 285.4 | 112.3 | 2.54 | 0.68 | 5.3 | 2649600 | 164 | 12703 | 810 |

5.0 WATER DISTRIBUTION SAMPLING (TREATED)

Third Party Analysis (CARO Analytical Services)

- Samples taken once per week at eight locations around the BMID service area
- 41 samples were found to be absent of Coliforms.
- 41 samples were found to be absent of *E. Coli*.

Table 5.1 - CARO Independent Lab

| Date | PRV 7 | | Booster 1 | | Ellison Blow-Off | | Ellison School | | 612 Adams Rd | | 3976 Highway 97 | | Prospect Reservoir | | Tower Reservoir | | Well #5 | |
|-----------|-----------|--------|-----------|--------|------------------|--------|----------------|--------|--------------|--------|-----------------|--------|--------------------|--------|-----------------|--------|-----------|--------|
| | Coliforms | E.coli | Coliforms | E.coli | Coliforms | E.coli | Coliforms | E.coli | Coliforms | E.coli | Coliforms | E.coli | Coliforms | E.coli | Coliforms | E.coli | Coliforms | E.coli |
| 4-Apr-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 11-Apr-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 18-Apr-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 25-Apr-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 4-May-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | - | - |
| 8-May-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 16-May-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | - | - |
| 24-May-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | - | - |
| 30-May-18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | - | - |

Testing – Total Coliforms – E.Coli

In-House Analysis (BMID Staff)

- Presence/Absence samples taken on a three week cycle at ten sites around the BMID service area.
- All samples were found to be absent of both Total Coliforms and *E. Coli*.

Table 5.2 - BMID In-house Testing – Presence Absence

| Location | 5/7/2018 | | | | 5/14/2018 | | | | 5/22/2018 | | | | 5/28/2018 | | | | | | | |
|----------------|----------|-------|-------|------|-----------|-------|-------|------|-----------|-------|-------|------|-----------|-------|-------|------|------|------|---|---|
| | CI2 | Temp. | Pres. | Abs. | CI2 | Temp. | Pres. | Abs. | CI2 | Temp. | Pres. | Abs. | CI2 | Temp. | Pres. | Abs. | | | | |
| Sylvania Cres | 0.68 | 11.0 | - | X | 0.50 | 13.4 | - | X | 1.44 | 12.0 | - | X | 0.08 | 15.0 | - | X | | | | |
| 170 Kneller Rd | 0.91 | 10.6 | - | X | | | | | | | | | 1.07 | 13.0 | - | X | | | | |
| 2105 Morrison | | | | | | | | | | | | | | | | | | | | |
| Pearson School | 1.09 | 11.0 | - | X | 0.68 | 14.0 | - | X | | | | | | | | | 1.33 | 13.0 | - | X |
| Staymen Rd | | | | | | | | | | | | | | | | | | | | |
| PRV #10 | | | | | | | | | | | | | | | | | | | | |
| 260 Campion Rd | 1.09 | 11.0 | - | X | 0.59 | 16.0 | - | X | 1.04 | 12.0 | - | X | | | | | | | | |
| Fenwick Rd | | | | | | | | | 1.34 | 12.0 | - | X | | | | | | | | |
| 2931 Belgo Rd | | | | | | | | | 1.38 | 13.0 | - | X | | | | | | | | |
| Solly Ct | | | | | | | | | | | | | | | | | | | | |

- BMID Population = 22,550

RECOMMENDED TESTS

- Recommended number of samples per month = 22
(as per Guide for Canadian Drinking Water Quality)

ACTUAL TESTS

- Total tests by BMID staff (presence/absence) = 13
- Total tests sampled by BMID and tested by Caro Labs = 41
- Total tests sampled in BMID treated distribution system = 54 (Zero Positive Samples)