



## MONTHLY REPORTING PERIOD - OCTOBER, 2024

### SUMMARY

This document provides a summary of the water quantity and quality information collected by BMID in October 2024. Documentation and figures are provided on the following pages to support this submission.

### WATER SUPPLY & USAGE SUMMARY

1. Water usage data for October, 2024 is as follows:

| Source                         | Total (US Gallons) | Total (Mega Litres) |
|--------------------------------|--------------------|---------------------|
| Mission Creek                  | 115,138,679        | 435.80              |
| Well 4                         | 4,273,837          | 16.18               |
| Well 5                         | 0                  | 0                   |
| Well 6 (Irrigation Only)       | 0                  | 0                   |
| Scotty Creek (Irrigation Only) | 0                  | 0                   |
| Total                          | 119,412,517        | 451.98              |

2. BMID began withdrawing stored water from high-elevation reservoirs in the summer to supplement Mission Creek flows. BMID continued to utilize the upper elevation reservoirs throughout October;
3. The Scotty Creek source, used to supplement irrigation flows in the north-end of the system during periods of high irrigation demands, was placed in stand-by mode for the year on September 3<sup>rd</sup>. Scotty Creek remained in stand-by mode for all of October and will remain off until summer 2025 ;
4. Well #5, used as the primary water source in the north-end of the system for both irrigation and domestic consumption during high consumption periods, was placed in stand-by mode on Sep 17<sup>th</sup> and will remain in stand-by until summer 2025;
5. Well #4, used as a primary source for domestic water in the north-end of the distribution system during low-flow periods was in operation throughout October. Well #4 will remain operational for the remainder of the year as system flows reduce during the autumn and into the winter;
6. Well #6, which supplies water to the north-end irrigation distribution system during times of high irrigation demands, ceased operations on September 24<sup>th</sup>. Well #6 will resume operation in summer 2025;
7. A portion of the BMID's transmission main west of the Mission Creek Intake and east of the tunnel is located on an unstable slope. Slope movement continues to be monitored. It is currently stable and is not moving;

---

## WATER QUALITY SUMMARY

1. BMID is investigating the use of Well #6 as a possible future potable water source. Quarterly samples were taken at the well on October 28<sup>th</sup>. Testing will continue for the next year to verify its water quality characteristics;
2. The WTP was in operation throughout most of October as Mission Creek experienced increased turbidity and colour in the raw water. The WTP was turned off on October 29<sup>th</sup> to drain the reservoirs and allow for seasonal maintenance during a planned shut-down of the Mission Creek source taking place on November 4<sup>th</sup>;
3. Raw water turbidity levels in Mission Creek peaked, due to a rainfall event, at 1.62 NTU on October 19<sup>th</sup>. Average daily raw water turbidity for October was 0.67 NTU at the Grit Pond;
4. The highest turbidity level at the Distribution Intake was 0.43 NTU on October 24<sup>th</sup> 2024. Average settled water turbidity for October was 0.31 NTU at the Distribution Intake at the lower end of Hadden Reservoir. The lowest daily average recording was 0.22 NTU on October 5<sup>th</sup>, 2024;
5. The highest turbidity level at the first customer (Booster #1) was 0.35 NTU on October 31<sup>st</sup>. Average monthly turbidity at the first customer was 0.27 NTU, while the lowest daily average turbidity was 0.16 NTU on October 7<sup>th</sup>-8<sup>th</sup>;
6. Average daily turbidity at the UV station peaked at 0.54 NTU on October 30<sup>th</sup> and 31<sup>st</sup>. Average monthly turbidity at the UV disinfection station was 0.45 NTU;
7. BMID's Ultraviolet Treatment Facility treated 435,847 m<sup>3</sup> of water, 126 m<sup>3</sup> of which was Off-Spec (0.029%);
8. Regarding microbiological readings, BMID resumed withdrawing water from the upper elevation reservoirs in mid-summer. As water continued to be withdrawn from the upper elevation reservoirs, there was an expected increase in microbiological readings;
9. Disinfection byproduct testing took place on October 9<sup>th</sup>. All THM samples are within the acceptable limits as set out in the Guidelines for Canadian Drinking Water Quality (Below 0.10 mg/L). 2 of the 4 surface water source samples had HAA results above the guideline (below 0.08 mg/L) however, average annual THM and HAA results meet the Canadian Drinking Water Quality Guidelines;
10. *E.Coli* levels at Mission Creek's Point-of-Diversion (creek intake prior to WTP) had normal counts for October. The October 28<sup>th</sup> sample had the peak count of 62 *E.Coli* Coliforms. The average monthly *E.Coli* count was 18.4, based on 5 samples;
11. *E.Coli* levels in the raw water at the water distribution system intake at the east end of Hadden Reservoir, immediately prior to disinfection, had zero counts on all five samples. Reduction in *E.Coli* levels is due to the effectiveness of the Water Treatment Plant as well as the settling of particles as water passes through Stevens and Hadden Reservoirs;
12. No *E.Coli* or *Total* Coliforms were found in treated water in the distribution system through third-party analysis. In addition, zero positive samples were detected by BMID's in-house presence/absence testing throughout October;


## 1.0 FLOWS - OCTOBER, 2024

The Maximum Daily Flow was on October 4<sup>th</sup> at 6,730,375 US gallons (25.47 ML)

The Minimum Daily Flow was on October 29<sup>th</sup>, at 2,066,221 US gallons (7.82 ML)

Mission Creek provided just over 96% of domestic and irrigation flow supplied in October.

**Figure 1.1 - Domestic Water System Flow**



**Table 1.2 - October 2024 - Daily Consumption Report**

| Year         | Mission Cr  | Well #4   | Well #5 | System Total | System Total |
|--------------|-------------|-----------|---------|--------------|--------------|
| 2024         | Usgpd       | Usgpd     | Usgpd   | Usgpd        | ML/Day       |
| 1-Oct        | 4,338,523   | 203,062   | -       | 4,541,585    | 17.19        |
| 2-Oct        | 5,064,124   | 172,059   | -       | 5,236,184    | 19.82        |
| 3-Oct        | 6,555,058   | 136,085   | -       | 6,691,143    | 25.33        |
| 4-Oct        | 6,560,976   | 169,399   | -       | 6,730,375    | 25.47        |
| 5-Oct        | 5,974,620   | 174,513   | -       | 6,149,133    | 23.27        |
| 6-Oct        | 5,977,948   | 179,107   | -       | 6,157,055    | 23.30        |
| 7-Oct        | 5,425,617   | 172,564   | -       | 5,598,181    | 21.19        |
| 8-Oct        | 5,428,048   | 178,946   | -       | 5,606,994    | 21.22        |
| 9-Oct        | 5,307,797   | 166,578   | -       | 5,474,374    | 20.72        |
| 10-Oct       | 4,737,423   | 167,235   | -       | 4,904,658    | 18.56        |
| 11-Oct       | 4,739,906   | 149,393   | -       | 4,889,300    | 18.51        |
| 12-Oct       | 4,459,012   | 170,884   | -       | 4,629,896    | 17.52        |
| 13-Oct       | 3,756,499   | 167,772   | -       | 3,924,271    | 14.85        |
| 14-Oct       | 3,421,952   | 170,049   | -       | 3,592,001    | 13.60        |
| 15-Oct       | 2,992,038   | 129,845   | -       | 3,121,883    | 11.82        |
| 16-Oct       | 3,009,870   | 187,566   | -       | 3,197,436    | 12.10        |
| 17-Oct       | 2,706,918   | 143,553   | -       | 2,850,470    | 10.79        |
| 18-Oct       | 2,497,826   | 140,647   | -       | 2,638,472    | 9.99         |
| 19-Oct       | 2,498,803   | 114,615   | -       | 2,613,418    | 9.89         |
| 20-Oct       | 2,241,367   | 123,708   | -       | 2,365,076    | 8.95         |
| 21-Oct       | 3,335,964   | 113,345   | -       | 3,449,309    | 13.06        |
| 22-Oct       | 3,336,994   | 127,127   | -       | 3,464,121    | 13.11        |
| 23-Oct       | 2,547,146   | 105,097   | -       | 2,652,244    | 10.04        |
| 24-Oct       | 2,121,275   | 93,870    | -       | 2,215,145    | 8.38         |
| 25-Oct       | 2,517,744   | 84,521    | -       | 2,602,265    | 9.85         |
| 26-Oct       | 2,518,669   | 80,477    | -       | 2,599,145    | 9.84         |
| 27-Oct       | 2,037,876   | 106,807   | -       | 2,144,682    | 8.12         |
| 28-Oct       | 2,038,721   | 80,601    | -       | 2,119,322    | 8.02         |
| 29-Oct       | 1,983,271   | 82,949    | -       | 2,066,221    | 7.82         |
| 30-Oct       | 2,502,924   | 101,378   | -       | 2,604,302    | 9.86         |
| 31-Oct       | 2,503,769   | 80,086    | -       | 2,583,855    | 9.78         |
| Totals Usgpd | 115,138,679 | 4,273,837 | 0       | 119,412,517  | 451.98       |
| Totals ML    | 435.80      | 16.18     | 0.00    |              |              |
| Avg's        | 3,714,151   | 14.06     |         | 3,894,289    | 14.58        |
| Max          | 6,560,976   | 24.83     |         | 6,730,375    | 25.47        |
| Min          | 1,983,271   | 7.51      |         | 2,066,221    | 7.82         |


## 2.0 RAW WATER QUALITY - BACTERIOLOGICAL MONITORING

Raw water samples were taken at three points at BMID settling ponds before chlorination. Samples were taken at the Mission Creek raw water intake, the outlet for Stevens Pond, and the point of disinfection at the end of Hadden Reservoir.

Samples from the previous month are also provided to show a two-month trend

The E.Coli readings confirm the WTP’s effectiveness in reducing raw water quality risks with coagulation, flocculation and sedimentation processes followed by settling times across Stevens and Hadden Reservoirs.

**Figure 2.1 - Raw Water E.Coli Readings (CARO Lab results) September 2024 - October 2024**



**Table 2.1 - E.Coli Readings (CARO Labs)**

| Date      | Mission Creek Raw Water Intake E.Coli | Stevens Pond Outlet E.Coli | Distribution Intake Hadden Pond E.Coli |
|-----------|---------------------------------------|----------------------------|--|
| 3-Sep-24  | 4                                     | 3                          | 0                                      |
| 9-Sep-24  | 2                                     | 1                          | 2                                      |
| 16-Sep-24 | 1                                     | 1                          | 0                                      |
| 23-Sep-24 | 5                                     | 0                          | 0                                      |
| 1-Oct-24  | 1                                     | 0                          | 0                                      |
| 9-Oct-24  | 0                                     | 0                          | 0                                      |
| 15-Oct-24 | 1                                     | 0                          | 0                                      |
| 21-Oct-24 | 28                                    | 0                          | 0                                      |
| 28-Oct-24 | 62                                    | 0                          | 0                                      |

Stevens or WTP Intake (Raw) - Sampling of raw water at intake from Mission Creek

Stevens Outlet (Raw) - Sampling point after exiting 142,000 m<sup>3</sup> 1<sup>st</sup> upper balancing reservoir (Stevens Res.)

Hadden Outlet (Raw) - Sampling point after exiting 75,000 m<sup>3</sup> 2<sup>nd</sup> lower balancing reservoir (Hadden Res.)


(Hadden Outlet = Distribution Intake - Point of Disinfection)

### 3.0 RAW AND TREATED WATER TURBIDITY

Turbidity is measured online at four locations, Mission Creek raw water intake, the Distribution Intake, the UV treatment plant, and Booster#1. The first user of the BMID system is located near Booster #1. The highest turbidity level recorded at this location was 0.35 NTU on October 31<sup>st</sup>, 2024. The lowest turbidity level was 0.16 NTU and the average turbidity was 0.27 NTU.

The distribution intake is where the water leaves Hadden Reservoir and enters a closed conduit. Turbidity levels are greatly reduced through the settling process as Mission Creek water makes its way through the reservoirs.

**Figure 3.1 – Daily Turbidity Readings (Mission Creek Raw - Distribution Intake - Booster Station 1 and UV Plant)**



**Table 3.1 - Daily Monitoring Record – Turbidity at On-Line Turbidity Analyzers**


| Turbidity Point Sampling for October 2024 |                      |                     |                       |                     |
|---|----------------------|---------------------|-----------------------|---------------------|
| Date                                      | Mission Creek Intake | Distribution Intake | Booster#1- First User | UV Plant            |
|   | Daily Average [NTU]  | Daily Average [NTU] | Daily Average [NTU]   | Daily Average [NTU] |
| 1   | 0.57                 | 0.24                | 0.18                  | 0.36                |
| 2   | 0.80                 | 0.25                | 0.24                  | 0.36                |
| 3   | 0.54                 | 0.23                | 0.27                  | 0.37                |
| 4   | 0.47                 | 0.23                | 0.21                  | 0.36                |
| 5   | 0.50                 | 0.22                | 0.26                  | 0.38                |
| 6   | 0.51                 | 0.23                | 0.18                  | 0.35                |
| 7   | 0.50                 | 0.30                | 0.16                  | 0.36                |
| 8   | 0.47                 | 0.26                | 0.16                  | 0.36                |
| 9   | 0.46                 | 0.23                | 0.21                  | 0.35                |
| 10  | 0.42                 | 0.25                | 0.26                  | 0.37                |
| 11  | 0.43                 | 0.27                | 0.29                  | 0.41                |
| 12  | 0.40                 | 0.28                | 0.31                  | 0.43                |
| 13  | 0.43                 | 0.28                | 0.28                  | 0.45                |
| 14  | 0.46                 | 0.29                | 0.28                  | 0.46                |
| 15  | 1.28                 | 0.33                | 0.27                  | 0.47                |
| 16  | 0.97                 | 0.29                | 0.27                  | 0.47                |
| 17  | 0.45                 | 0.32                | 0.29                  | 0.47                |
| 18  | 0.44                 | 0.31                | 0.29                  | 0.48                |
| 19  | 1.62                 | 0.30                | 0.29                  | 0.48                |
| 20  | 0.94                 | 0.35                | 0.30                  | 0.49                |
| 21  | 0.57                 | 0.34                | 0.30                  | 0.49                |
| 22  | 0.60                 | 0.36                | 0.30                  | 0.50                |
| 23  | 0.62                 | 0.36                | 0.30                  | 0.49                |
| 24  | 0.59                 | 0.43                | 0.29                  | 0.49                |
| 25  | 0.64                 | 0.41                | 0.32                  | 0.51                |
| 26  | 1.50                 | 0.37                | 0.32                  | 0.49                |
| 27  | 1.20                 | 0.38                | 0.31                  | 0.50                |
| 28  | 0.72                 | 0.38                | 0.32                  | 0.52                |
| 29  | 0.68                 | 0.36                | 0.31                  | 0.52                |
| 30  | 0.56                 | 0.35                | 0.34                  | 0.54                |
| 31  | 0.60                 | 0.36                | 0.35                  | 0.54                |
| Average                                   | 0.67                 | 0.31                | 0.27                  | 0.45                |



### 4.0 CHLORINE CONTACT TIME

Temperature, pH, peak flow and chlorine residual levels are recorded to determine the CT levels that are required to provide 3 log inactivation of *Giardia*. Chlorine Contact times exceeded the CT levels required to provide 3 log (99.9%) inactivation of *Giardia Lamblia* throughout the month of October, 2024.

Figure 4.1 - CT Trending – BMID Mission Creek Source – October 2024



CTa – CT achieved  
 CTr – CT Required

The minimum CT that BMID achieved was 3.63 X that of what was required

Table 4.2 - CT Table – Mission Creek Source


| BMID October 2024    |           |           |         |                      |          |        |         |                      |                 |         |        |               |                        |
|----------------------|-----------|-----------|---------|----------------------|----------|--------|---------|----------------------|-----------------|---------|--------|---------------|------------------------|
| Mission Creek Source |           |           |         |                      |          |        |         |                      |                 |         |        |               |                        |
| DATE                 | pH        | TEMP      | PEAK    | Free Cl <sub>2</sub> | CT       | CT     | CTa/CTr | Free Cl <sub>2</sub> | Cl <sub>2</sub> | VOLUME  | TIME   | FLOW          | CL <sub>2</sub> DOSAGE |
|                      | (Average) | (Present) | FLOW    | residual             | achieved | req'd  |         | Req'd                | Dosage          | TOTAL   | [mins] | Daily Average | Average                |
| October              |           | [°C]      | [Usgpm] | [mg/L]               |          |        |         | [mg/L]               | [mg/L]          | [USgal] |        | [USGPM]       | [PPD]                  |
| 1                    | 7.25      | 12.8      | 5,247   | 1.43                 | 722.1    | 107.5  | 6.72    | 0.21                 | 3.3             | 2649600 | 505    | 3,033         | 120                    |
| 2                    | 7.25      | 12.7      | 6,776   | 1.30                 | 508.3    | 106.7  | 4.76    | 0.27                 | 3.2             | 2649600 | 391    | 3,606         | 141                    |
| 3                    | 7.24      | 12.5      | 6,993   | 1.35                 | 511.5    | 108.4  | 4.72    | 0.29                 | 3.2             | 2649600 | 379    | 4,639         | 178                    |
| 4                    | 7.25      | 11.5      | 5,649   | 1.36                 | 637.9    | 116.7  | 5.46    | 0.25                 | 3.2             | 2649600 | 469    | 3,582         | 140                    |
| 5                    | 7.25      | 11.1      | 8,890   | 1.48                 | 441.1    | 121.5  | 3.63    | 0.41                 | 3.2             | 2649600 | 298    | 4,240         | 163                    |
| 6                    | 7.25      | 10.6      | 6,174   | 1.53                 | 656.6    | 126.5  | 5.19    | 0.29                 | 3.2             | 2649600 | 429    | 3,811         | 145                    |
| 7                    | 7.27      | 10.9      | 5,866   | 1.41                 | 636.9    | 123.3  | 5.17    | 0.27                 | 3.1             | 2649600 | 452    | 3,833         | 145                    |
| 8                    | 7.28      | 10.5      | 6,964   | 1.44                 | 547.9    | 127.6  | 4.29    | 0.34                 | 3.1             | 2649600 | 380    | 3,757         | 142                    |
| 9                    | 7.25      | 10.7      | 5,201   | 1.56                 | 794.7    | 126.0  | 6.31    | 0.25                 | 3.2             | 2649600 | 509    | 2,969         | 115                    |
| 10                   | 7.26      | 11.0      | 4,884   | 1.75                 | 949.3    | 126.0  | 7.54    | 0.23                 | 3.3             | 2649600 | 542    | 3,349         | 131                    |
| 11                   | 7.23      | 10.6      | 6,036   | 1.89                 | 829.7    | 129.6  | 6.40    | 0.30                 | 3.2             | 2649600 | 439    | 3,151         | 121                    |
| 12                   | 7.22      | 10.5      | 4,910   | 1.72                 | 928.1    | 128.2  | 7.24    | 0.24                 | 3.2             | 2649600 | 540    | 2,650         | 101                    |
| 13                   | 7.21      | 10.1      | 4,527   | 1.58                 | 924.8    | 129.6  | 7.14    | 0.22                 | 3.2             | 2649600 | 585    | 2,418         | 94                     |
| 14                   | 7.20      | 10.1      | 5,215   | 1.42                 | 721.5    | 127.1  | 5.68    | 0.25                 | 3.3             | 2649600 | 508    | 1,995         | 79                     |
| 15                   | 7.21      | 9.9       | 4,528   | 1.48                 | 865.9    | 130.1  | 6.65    | 0.22                 | 3.3             | 2649600 | 585    | 2,104         | 83                     |
| 16                   | 7.20      | 10.4      | 3,331   | 1.44                 | 1145.4   | 124.7  | 9.18    | 0.16                 | 3.3             | 2649600 | 795    | 1,874         | 75                     |
| 17                   | 7.19      | 10.3      | 2,859   | 1.44                 | 1334.3   | 125.1  | 10.66   | 0.14                 | 3.4             | 2649600 | 927    | 1,625         | 66                     |
| 18                   | 7.20      | 10.0      | 3,322   | 1.48                 | 1180.4   | 128.8  | 9.17    | 0.16                 | 3.4             | 2649600 | 798    | 1,761         | 71                     |
| 19                   | 7.23      | 9.3       | 2,259   | 1.43                 | 1677.5   | 136.0  | 12.34   | 0.12                 | 7.3             | 2649600 | 1173   | 746           | 65                     |
| 20                   | 7.18      | 8.7       | 2,008   | 1.37                 | 1807.5   | 138.2  | 13.07   | 0.10                 | 3.4             | 2649600 | 1319   | 1,503         | 62                     |
| 21                   | 7.17      | 9.2       | 2,711   | 1.40                 | 1368.2   | 133.5  | 10.25   | 0.14                 | 3.4             | 2649600 | 977    | 1,593         | 65                     |
| 22                   | 7.17      | 9.4       | 2,389   | 1.38                 | 1530.8   | 131.3  | 11.65   | 0.12                 | 3.4             | 2649600 | 1109   | 1,528         | 63                     |
| 23                   | 7.17      | 8.9       | 2,210   | 1.28                 | 1534.9   | 134.5  | 11.42   | 0.11                 | 3.5             | 2649600 | 1199   | 1,492         | 62                     |
| 24                   | 7.16      | 8.3       | 3,016   | 1.14                 | 1001.4   | 137.2  | 7.30    | 0.16                 | 6.0             | 2649600 | 878    | 819           | 60                     |
| 25                   | 7.15      | 7.8       | 4,214   | 1.41                 | 886.6    | 146.1  | 6.07    | 0.23                 | 3.4             | 2649600 | 629    | 1,775         | 72                     |
| 26                   | 7.16      | 7.4       | 2,024   | 1.47                 | 1924.3   | 151.8  | 12.68   | 0.12                 | 3.5             | 2649600 | 1309   | 1,376         | 58                     |
| 27                   | 7.17      | 7.4       | 2,081   | 1.34                 | 1706.0   | 150.2  | 11.36   | 0.12                 | 3.5             | 2649600 | 1273   | 1,434         | 60                     |
| 28                   | 7.16      | 7.9       | 1,977   | 1.40                 | 1876.0   | 145.5  | 12.89   | 0.11                 | 3.5             | 2649600 | 1340   | 1,400         | 59                     |
| 29                   | 7.16      | 7.7       | 2,024   | 1.41                 | 1845.7   | 147.7  | 12.50   | 0.11                 | 3.6             | 2649600 | 1309   | 1,246         | 53                     |
| 30                   | 7.15      | 7.3       | 3,227   | 1.48                 | 1215.1   | 152.4  | 7.97    | 0.19                 | 3.4             | 2649600 | 821    | 1,766         | 71                     |
| 31                   | 7.15      | 7.6       | 2,006   | 1.49                 | 1968.2   | 149.4  | 13.17   | 0.11                 | 3.6             | 2649600 | 1321   | 1,250         | 54                     |
| Averages             |           | 9.78      | 4,142   | 1.45                 | 1118.67  | 131.19 | 8.34    | 0.20                 | 3.54            |         |        |               |                        |

## 5.0 ULTRAVIOLET DISINFECTION

|                      |                        |         |
|----------------------|------------------------|---------|
| Total Water Treated: | 435,847 m <sup>3</sup> | 100.00% |
| On-Spec Water:       | 435,721 m <sup>3</sup> | 99.971% |
| Off-Spec Water:      | 126 m <sup>3</sup>     | 0.029%  |

Average monthly chlorine residual before UV Treatment was 1.57 mg/L  
The average monthly chlorine residual after UV treatment and re-chlorination was 1.45 mg/L.

**Figure 5.1 - UV Disinfection – BMID Mission Creek Source – October 2024**



**Table 5.2 - UV Disinfection Table – Mission Creek Source**

| Date           | Inlet Cl2   | Outlet Cl2  | UVT          | Turbidity   |              | In Spec Water     | Off Spec     | Off Spec %    |
|----------------|-------------|-------------|--------------|-------------|--------------|-------------------|--------------|---------------|
|                | Daily       | Daily       |              |             |              |                   |              |               |
|                | mg/L        | mg/L        | % T          | NTU         |              | Cubic Meters      | Cubic Meters | Percentage    |
| 1-Oct          | 1.43        | 1.40        | 91.0         | 0.36        |              | 16,423            | 0            | 0.00%         |
| 2-Oct          | 1.45        | 1.43        | 91.4         | 0.36        |              | 19,170            | 0            | 0.00%         |
| 3-Oct          | 1.70        | 1.57        | 91.2         | 0.37        |              | 24,814            | 0            | 0.00%         |
| 4-Oct          | 1.65        | 1.50        | 91.1         | 0.36        |              | 24,836            | 0            | 0.00%         |
| 5-Oct          | 1.60        | 1.52        | 90.8         | 0.38        |              | 22,616            | 0            | 0.00%         |
| 6-Oct          | 1.64        | 1.56        | 90.9         | 0.35        |              | 22,629            | 0            | 0.00%         |
| 7-Oct          | 1.43        | 1.40        | 91.1         | 0.36        |              | 20,538            | 0            | 0.00%         |
| 8-Oct          | 1.56        | 1.43        | 91.6         | 0.36        |              | 20,547            | 0            | 0.00%         |
| 9-Oct          | 1.65        | 1.40        | 91.6         | 0.35        |              | 20,092            | 0            | 0.00%         |
| 10-Oct         | 1.41        | 1.51        | 91.4         | 0.37        |              | 17,933            | 0            | 0.00%         |
| 11-Oct         | 1.68        | 1.64        | 91.3         | 0.41        |              | 17,943            | 0            | 0.00%         |
| 12-Oct         | 1.62        | 1.50        | 91.2         | 0.43        |              | 16,879            | 0            | 0.00%         |
| 13-Oct         | 1.89        | 1.46        | 91.0         | 0.45        |              | 14,220            | 0            | 0.00%         |
| 14-Oct         | 1.73        | 1.40        | 91.0         | 0.46        |              | 12,954            | 0            | 0.00%         |
| 15-Oct         | 1.58        | 1.44        | 91.3         | 0.47        |              | 11,326            | 0            | 0.00%         |
| 16-Oct         | 1.53        | 1.41        | 91.7         | 0.47        |              | 11,331            | 63           | 0.00%         |
| 17-Oct         | 1.44        | 1.41        | 91.6         | 0.47        |              | 10,184            | 63           | 0.00%         |
| 18-Oct         | 1.29        | 1.38        | 91.5         | 0.48        |              | 9,455             | 0            | 0.00%         |
| 19-Oct         | 1.27        | 1.42        | 91.4         | 0.48        |              | 9,459             | 0            | 0.00%         |
| 20-Oct         | 1.50        | 1.40        | 91.3         | 0.49        |              | 8,485             | 0            | 0.00%         |
| 21-Oct         | 1.56        | 1.40        | 91.2         | 0.49        |              | 12,628            | 0            | 0.00%         |
| 22-Oct         | 1.52        | 1.40        | 91.1         | 0.50        |              | 12,632            | 0            | 0.00%         |
| 23-Oct         | 1.59        | 1.41        | 90.9         | 0.49        |              | 9,642             | 0            | 0.00%         |
| 24-Oct         | 1.63        | 1.41        | 90.8         | 0.49        |              | 8,030             | 0            | 0.00%         |
| 25-Oct         | 1.68        | 1.49        | 90.6         | 0.51        |              | 9,531             | 0            | 0.00%         |
| 26-Oct         | 1.71        | 1.47        | 90.4         | 0.49        |              | 9,534             | 0            | 0.00%         |
| 27-Oct         | 1.73        | 1.48        | 90.3         | 0.50        |              | 7,714             | 0            | 0.00%         |
| 28-Oct         | 1.59        | 1.43        | 91.1         | 0.52        |              | 7,717             | 0            | 0.00%         |
| 29-Oct         | 1.43        | 1.43        | 91.6         | 0.52        |              | 7,508             | 0            | 0.00%         |
| 30-Oct         | 1.48        | 1.52        | 91.5         | 0.54        |              | 9,475             | 0            | 0.00%         |
| 31-Oct         | 1.65        | 1.45        | 91.3         | 0.54        |              | 9,478             | 0            | 0.00%         |
| <b>Average</b> | <b>1.57</b> | <b>1.45</b> | <b>91.17</b> | <b>0.45</b> | <b>Total</b> | <b>435,721.20</b> | <b>126</b>   | <b>0.029%</b> |

## 6.0 WATER DISTRIBUTION SAMPLING (TREATED)

### Third Party Analysis (CARO Analytical Services)

- Samples taken once per week at ten locations around the BMID service area
- 30 samples were found to be absent of Coliforms.
- 30 samples were found to be absent of *E. Coli*.

**Table 6.1 - CARO Independent Lab Testing – Total Coliforms – *E. Coli***

| Date      | 2921 Belgo Rd |        | Booster 1 |        | Elison Blow-Off |        | Elison School |        | 3976 Highway 97 |        | Prospect Reservoir |        | Tower Reservoir |        | Well #5   |        | Well #4   |        | Kirschner Res |        | Pearson School |        |
|-----------|---------------|--------|-----------|--------|-----------------|--------|---------------|--------|-----------------|--------|--------------------|--------|-----------------|--------|-----------|--------|-----------|--------|---------------|--------|----------------|--------|
|           | Coliforms     | E.coli | Coliforms | E.coli | Coliforms       | E.coli | Coliforms     | E.coli | Coliforms       | E.coli | Coliforms          | E.coli | Coliforms       | E.coli | Coliforms | E.coli | Coliforms | E.coli | Coliforms     | E.coli | Coliforms      | E.coli |
| 3-Sep-24  | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |
| 9-Sep-24  | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |
| 16-Sep-24 | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |
| 23-Sep-24 | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |
| 1-Oct-24  | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |
| 9-Oct-24  | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |
| 15-Oct-24 | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |
| 21-Oct-24 | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |
| 28-Oct-24 | 0             | 0      | 0         | 0      | 0               | 0      | 0             | 0      | 0               | 0      | 0                  | 0      | 0               | 0      | 0         | 0      | 0         | 0      | 0             | 0      | 0              | 0      |

### In-House Analysis (BMID Staff)

- Presence/Absence samples taken on a three-week cycle at seven sites around the BMID service area.
- All 12 samples were found to be absent of both *Total Coliforms* and *E. Coli*.

**Table 6.2 - BMID In-house Testing – Presence Absence**

| Location                 | 10/4/2024 |       |       |      | 10/9/2024 |       |       |      | 10/15/2024 |       |       |      | 10/21/2024 |       |       |      | 10/28/2024 |       |       |      |
|--------------------------|-----------|-------|-------|------|-----------|-------|-------|------|------------|-------|-------|------|------------|-------|-------|------|------------|-------|-------|------|
|                          | Cl2       | Temp. | Pres. | Abs. | Cl2       | Temp. | Pres. | Abs. | Cl2        | Temp. | Pres. | Abs. | Cl2        | Temp. | Pres. | Abs. | Cl2        | Temp. | Pres. | Abs. |
| Sylvania Cres            | 0.77      | 17.2  | -     | X    |           |       |       |      |            |       |       |      | 0.85       | 15.8  | -     | X    |            |       |       |      |
| 170 Kneller Rd           | 0.76      | 16.8  | -     | X    |           |       |       |      |            |       |       |      | 0.95       | 15.6  | -     | X    |            |       |       |      |
| 2105 Morrison Staymen Rd |           |       |       |      | 0.66      | 17.4  | -     | X    |            |       |       |      |            |       |       |      | 0.61       | 17.0  | -     | X    |
| 260 Campion Rd           |           |       |       |      | 0.64      | 16.2  | -     | X    |            |       |       |      |            |       |       |      | 0.56       | 16.0  | -     | X    |
| Fenwick Rd               |           |       |       |      |           |       |       |      | 0.01       | 17.2  | -     | X    |            |       |       |      |            |       |       |      |
| Solly Ct                 | 0.90      | 16.4  | -     | X    |           |       |       |      | 0.72       | 16.0  | -     | X    |            |       |       |      | 1.03       | 15.2  | -     | X    |

**Table 6.3 - BMID Disinfection By-product Testing – THM and HAA**

| 9-Oct-24            |            |               |
|---------------------|------------|---------------|
| Location            | THM (mg/L) | HAA (mg/L)    |
| Kirschner Reservoir | 0.0983     | <b>0.0838</b> |
| Pearson School      | 0.0972     | 0.0755        |
| 2921 Belgo Rd       | 0.0967     | <b>0.0990</b> |
| Ellison School*     | 0.0141     | <0.00200      |
| 3976 Hwy 97 N       | 0.0920     | 0.0777        |

\*Primarily Ground Water Supply

- THM quarterly averages are within the acceptable limits as set out in the Guidelines for Canadian Drinking Water Quality (Below 0.10 mg/L).
- HAA quarterly averages are slightly above the acceptable guideline (0.08 mg/L) however the annual averages are within the guidelines.



**7.0 WELL #6 POTENTIAL POTABILITY TESTING**

- Well #6 was sampled on Oct 28<sup>th</sup> for the following items:
  - Microbiological parameters
  - Anions, Calculated parameters, General parameters
  - Total Metals
- BMID will take monthly bacterial samples on the raw water at Well #6 to determine the potential potability of the source. Results are as follows:
  - A copy of CARO’s results will be included at the end of this report.

| Well 6 Bacterial Testing |                 |                  |
|--------------------------|-----------------|------------------|
| Date                     | Total Coliforms | E.Coli Coliforms |
| 24-Jun-24                | 0               | 0                |
| 29-Jul-24                | 0               | 0                |
| 26-Aug-24                | 0               | 0                |
| 28-Oct-24                | 0               | 0                |

- BMID Population = 28,000

**RECOMMENDED TESTS**

- Recommended number of samples per month = 28  
 (as per Guide for Canadian Drinking Water Quality)

**ACTUAL TESTS**

- Total tests by BMID staff (presence/absence) = 12
- Total tests sampled by BMID and tested by Caro Labs 30
- Total tests sampled in BMID treated distribution system = 42
- 0 Positive *E.Coli* and Total Coliform Samples

## TEST RESULTS

REPORTED TO PROJECT Black Mountain Irrigation District  
 Screen Works/ Chemistry

WORK ORDER REPORTED 24J3608  
 2024-11-03 19:22

| Analyte   | Result | RL   | Units    | Analyzed   | Qualifier |
|---|--------|------|----------|------------|-----------|
| <b>Screenworks (24J3608-01)   Matrix: Water   Sampled: 2024-10-28 10:01</b> |        |      |          |            |           |
| <i>Field Parameters</i>   |        |      |          |            |           |
| Chlorine, Free  | 2.38   | 0.02 | mg/L     | 2024-10-28 |           |
| Temperature, field  | 7.7    |      | °C       | 2024-10-28 |           |
| <i>General Parameters</i>   |        |      |          |            |           |
| Alkalinity, Total (as CaCO3)  | 36.7   | 1.0  | mg/L     | 2024-10-30 |           |
| Alkalinity, Phenolphthalein (as CaCO3)                                      | < 1.0  | 1.0  | mg/L     | 2024-10-30 |           |
| Alkalinity, Bicarbonate (as CaCO3)  | 36.7   | 1.0  | mg/L     | 2024-10-30 |           |
| Alkalinity, Carbonate (as CaCO3)  | < 1.0  | 1.0  | mg/L     | 2024-10-30 |           |
| Alkalinity, Hydroxide (as CaCO3)  | < 1.0  | 1.0  | mg/L     | 2024-10-30 |           |
| Colour, True  | < 5.0  | 5.0  | CU       | 2024-10-30 |           |
| Conductivity (EC)   | 124    | 2.0  | µS/cm    | 2024-10-30 |           |
| pH  | 7.43   | 0.10 | pH units | 2024-10-30 | HT2       |
| Turbidity   | 0.30   | 0.10 | NTU      | 2024-10-30 |           |
| UV Transmittance @ 254nm  | 91.6   | 0.10 | % T      | 2024-10-29 |           |

**Well #6 (24J3608-02) | Matrix: Water | Sampled: 2024-10-28 13:48**

|  |          |        |          |            |           |
|--|----------|--------|----------|------------|-----------|
| <i>Anions</i>                          |          |        |          |            |           |
| Chloride                               | 11.1     | 0.10   | mg/L     | 2024-10-29 |           |
| Fluoride                               | < 0.10   | 0.10   | mg/L     | 2024-10-29 |           |
| Nitrate (as N)                         | 1.49     | 0.010  | mg/L     | 2024-10-29 |           |
| Nitrite (as N)                         | < 0.010  | 0.010  | mg/L     | 2024-10-29 |           |
| Sulfate                                | 22.3     | 1.0    | mg/L     | 2024-10-29 |           |
| <i>Calculated Parameters</i>           |          |        |          |            |           |
| Hardness, Total (as CaCO3)             | 204      | 0.500  | mg/L     | N/A        |           |
| Langelier Index                        | 0.2      | -5.0   |          | 2024-11-01 | CT10, CT6 |
| Solids, Total Dissolved                | 235      | 1.00   | mg/L     | N/A        |           |
| <i>Field Parameters</i>                |          |        |          |            |           |
| Chlorine, Free                         | < 0.02   | 0.02   | mg/L     | 2024-10-28 |           |
| Temperature, field                     | 11.7     |        | °C       | 2024-10-28 |           |
| <i>General Parameters</i>              |          |        |          |            |           |
| Alkalinity, Total (as CaCO3)           | 177      | 1.0    | mg/L     | 2024-10-30 |           |
| Alkalinity, Phenolphthalein (as CaCO3) | < 1.0    | 1.0    | mg/L     | 2024-10-30 |           |
| Alkalinity, Bicarbonate (as CaCO3)     | 177      | 1.0    | mg/L     | 2024-10-30 |           |
| Alkalinity, Carbonate (as CaCO3)       | < 1.0    | 1.0    | mg/L     | 2024-10-30 |           |
| Alkalinity, Hydroxide (as CaCO3)       | < 1.0    | 1.0    | mg/L     | 2024-10-30 |           |
| Carbon, Dissolved Organic              | 1.14     | 0.50   | mg/L     | 2024-10-30 |           |
| Colour, True                           | < 5.0    | 5.0    | CU       | 2024-10-30 |           |
| Conductivity (EC)                      | 440      | 2.0    | µS/cm    | 2024-10-30 |           |
| Cyanide, Total                         | < 0.0020 | 0.0020 | mg/L     | 2024-10-31 | HT1       |
| pH                                     | 7.91     | 0.10   | pH units | 2024-10-30 | HT2       |





### TEST RESULTS

REPORTED TO Black Mountain Irrigation District  
 PROJECT Screen Works/ Chemistry

WORK ORDER 24J3608  
 REPORTED 2024-11-03 19:22

| Analyte  | Result     | RL       | Units | Analyzed   | Qualifier |
|--|------------|----------|-------|------------|-----------|
| <b>Well #6 (24J3608-02)   Matrix: Water   Sampled: 2024-10-28 13:48, Continued</b> |            |          |       |            |           |
| <i>General Parameters, Continued</i>   |            |          |       |            |           |
| Phosphorus, Total (as P)   | 0.0283     | 0.0050   | mg/L  | 2024-10-31 |           |
| Temperature, at pH   | 20.9       |          | °C    | 2024-10-30 | HT2       |
| Turbidity  | 0.41       | 0.10     | NTU   | 2024-10-30 |           |
| <i>Total Metals</i>  |            |          |       |            |           |
| Aluminum, total  | < 0.0050   | 0.0050   | mg/L  | 2024-10-30 |           |
| Antimony, total  | < 0.00020  | 0.00020  | mg/L  | 2024-10-30 |           |
| Arsenic, total   | < 0.00050  | 0.00050  | mg/L  | 2024-10-30 |           |
| Barium, total  | 0.0140     | 0.0050   | mg/L  | 2024-10-30 |           |
| Boron, total   | < 0.0500   | 0.0500   | mg/L  | 2024-10-30 |           |
| Cadmium, total   | < 0.000010 | 0.000010 | mg/L  | 2024-10-30 |           |
| Calcium, total   | 63.0       | 0.20     | mg/L  | 2024-10-30 |           |
| Chromium, total  | 0.00096    | 0.00050  | mg/L  | 2024-10-30 |           |
| Cobalt, total  | < 0.00010  | 0.00010  | mg/L  | 2024-10-30 |           |
| Copper, total  | < 0.00040  | 0.00040  | mg/L  | 2024-10-30 |           |
| Iron, total  | 0.029      | 0.010    | mg/L  | 2024-10-30 |           |
| Lead, total  | < 0.00020  | 0.00020  | mg/L  | 2024-10-30 |           |
| Magnesium, total   | 11.4       | 0.010    | mg/L  | 2024-10-31 |           |
| Manganese, total   | 0.00100    | 0.00020  | mg/L  | 2024-10-30 |           |
| Mercury, total   | < 0.000040 | 0.000040 | mg/L  | 2024-11-01 | HG1       |
| Molybdenum, total  | 0.00164    | 0.00010  | mg/L  | 2024-10-30 |           |
| Nickel, total  | 0.00048    | 0.00040  | mg/L  | 2024-10-30 |           |
| Potassium, total   | 1.84       | 0.10     | mg/L  | 2024-10-30 |           |
| Selenium, total  | 0.00092    | 0.00050  | mg/L  | 2024-10-30 |           |
| Sodium, total  | 11.6       | 0.10     | mg/L  | 2024-10-31 |           |
| Strontium, total   | 0.275      | 0.0010   | mg/L  | 2024-10-30 |           |
| Uranium, total   | 0.000940   | 0.000020 | mg/L  | 2024-10-30 |           |
| Zinc, total  | 0.0079     | 0.0040   | mg/L  | 2024-10-30 |           |

**Sample Qualifiers:**

- CT10 Results were based on lab pH.
- CT6 Results were based on lab temperature & lab pH.
- HG1 Sample bottle and preservation submitted is not suitable for Mercury analysis and analyte stability may be affected.
- HT1 The sample was prepared and/or analyzed past the recommended holding time.
- HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.