


BMID Turbidity November 2024 (Single Point Daily Sampling with Inline Hach 1720c)



	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	
Distribution Intake	0.32	0.35	0.31	0.37	0.48	0.46																									
Booster#1- First User	0.35	0.37	0.40	0.42	0.36	0.41	0.31	0.11	0.07	0.05	0.04	0.04	0.04	0.03	0.02	0.03	0.04	0.03	0.02	0.03	0.01	0.01	0.02	0.02	0.02	0.02	0.04	0.05	0.04	0.05	0.10
Mission Creek Intake	0.60	0.55	0.58	0.53	0.56	0.52	0.48	0.47	0.45	0.46	0.48	0.52	0.47	0.47	0.43	0.45	0.47	0.57	0.92	0.46	0.70	0.68	0.60	0.56	0.58	0.56	0.60	0.66	0.97	0.77	
UV Plant	0.54	0.56	0.57	0.57	0.58	0.56																									

Date