

**REPORTED TO** Black Mountain Irrigation District  
285 Gray Avenue  
KELOWNA, BC V1X 1W8

**TEL** (250) 765-5169  
**FAX** (250) 765-0277

**ATTENTION** BMID Reports

**WORK ORDER** 7061958

**PO NUMBER**

**RECEIVED / TEMP** 2017-06-21 12:45 / 14°C

**PROJECT** Comprehensive

**REPORTED** 2017-06-28

**PROJECT INFO**

**COC NUMBER** B51181

**General Comments:**

CARO Analytical Services employs methods which are conducted according to procedures accepted by appropriate regulatory agencies, and/or are conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts, except where otherwise agreed to by the client.

The results in this report apply to the samples analyzed in accordance with the Chain of Custody or Sample Requisition document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing.



Authorized By:

**Jennifer Shanko, A.Sc.T.**  
Account Manager

*If you have any questions or concerns, please contact me at [jshanko@caro.ca](mailto:jshanko@caro.ca)*

**Locations:**

#110 4011 Viking Way  
Richmond, BC V6V 2K9  
Tel: 604-279-1499

#102 3677 Highway 97N  
Kelowna, BC V1X 5C3  
Tel: 250-765-9646

17225 109 Avenue  
Edmonton, AB T5S 1H7  
Tel: 780-489-9100

[www.caro.ca](http://www.caro.ca)

**REPORTED TO PROJECT** Black Mountain Irrigation District  
Comprehensive

**WORK ORDER REPORTED** 7061958  
2017-06-28

Analysis Description	Method Reference	Technique	Location
Alkalinity in Water	APHA 2320 B*	Titration with H2SO4	Kelowna
Anions by IC in Water	APHA 4110 B	Ion Chromatography with Chemical Suppression of Eluent Conductivity	Kelowna
Coliforms, Total (MF-CCA) in Water	APHA 9222*	Membrane Filtration / Incubation on Chromocult Agar	Kelowna
Colour, True in Water	APHA 2120 C	Spectrophotometry (456 nm)	Kelowna
Conductivity in Water	APHA 2510 B	Conductivity Meter	Kelowna
Cyanide, SAD in Water	ASTM D7511-12	Flow Injection Analysis with In-Line Ultraviolet Digestion and Amperometric Detection	Kelowna
E. coli (MF-CCA) in Water	APHA 9222*	Membrane Filtration / Incubation on Chromocult Agar	Kelowna
Hardness (as CaCO3) in Water	APHA 2340 B*	Calculation: 2.497 [total Ca] + 4.118 [total Mg] (Estimated)	N/A
Langelier Index in Water	APHA 2330 B	Calculation	N/A
Mercury, total by CVAFS in Water	EPA 245.7*	BrCl2 Oxidation / Cold Vapor Atomic Fluorescence Spectrometry (CVAFS)	Richmond
pH in Water	APHA 4500-H+ B	Electrometry	Kelowna
Solids, Total Dissolved (calc) in Water	APHA 1030 E	Calculation: 100 x ([Cations]-[Anions])/([Cations]+[Anions])	N/A
Temperature (lab) in Water	APHA 2550 B	Thermometer	Kelowna
Total Metals by ICPMS in Water	APHA 3030 E* / APHA 3125 B	HNO3+HCl Hot Block Digestion / Inductively Coupled Plasma Mass Spectrometry (ICP-MS)	Richmond
Turbidity in Water	APHA 2130 B	Nephelometry	Kelowna

**Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method**

**Method Reference Descriptions:**

APHA Standard Methods for the Examination of Water and Wastewater, 22nd Edition, American Public Health Association/American Water Works Association/Water Environment Federation  
 ASTM ASTM International Test Methods  
 EPA United States Environmental Protection Agency Test Methods

**Glossary of Terms:**

MRL Method Reporting Limit  
 < Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences  
 °C Degrees Celcius  
 CFU/100 mL Colony Forming Units per 100 millilitres  
 CU Colour Units (referenced against a platinum cobalt standard)  
 mg/L Milligrams per litre  
 NTU Nephelometric Turbidity Units  
 pH units pH < 7 = acidic, pH > 7 = basic  
 µS/cm Microsiemens per centimetre

**REPORTED TO PROJECT** Black Mountain Irrigation District  
Comprehensive

**WORK ORDER REPORTED** 7061958  
2017-06-28

Analyte	Result / Recovery	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	--------------	-------	----------	----------	-------

**Sample ID: Booster #1 (7061958-01) [Water] Sampled: 2017-06-21 08:00**

**Anions**

Chloride	9.09	0.10	mg/L	N/A	2017-06-22	
Fluoride	< 0.10	0.10	mg/L	N/A	2017-06-22	
Nitrate (as N)	< 0.010	0.010	mg/L	N/A	2017-06-22	
Nitrite (as N)	< 0.010	0.010	mg/L	N/A	2017-06-22	
Sulfate	1.6	1.0	mg/L	N/A	2017-06-22	

**General Parameters**

Alkalinity, Total (as CaCO3)	12.0	1.0	mg/L	N/A	2017-06-24	
Alkalinity, Phenolphthalein (as CaCO3)	< 1.0	1.0	mg/L	N/A	2017-06-24	
Alkalinity, Bicarbonate (as CaCO3)	12.0	1.0	mg/L	N/A	2017-06-24	
Alkalinity, Carbonate (as CaCO3)	< 1.0	1.0	mg/L	N/A	2017-06-24	
Alkalinity, Hydroxide (as CaCO3)	< 1.0	1.0	mg/L	N/A	2017-06-24	
Colour, True	< 5.0	5.0	CU	N/A	2017-06-23	
Conductivity (EC)	62.3	2.0	µS/cm	N/A	2017-06-24	
Cyanide, Total	0.0048	0.0020	mg/L	N/A	2017-06-27	
pH	6.96	0.01	pH units	N/A	2017-06-24	HT2
Temperature, at pH	23		°C	N/A	2017-06-24	HT2
Turbidity	0.35	0.10	NTU	N/A	2017-06-21	

**Calculated Parameters**

Hardness, Total (as CaCO3)	20.2	0.500	mg/L	N/A	N/A	
Langelier Index	-2.6	-5.0	-	N/A	2017-06-28	
Solids, Total Dissolved (calc)	29.6	1.00	mg/L	N/A	N/A	

**Total Metals**

Aluminum, total	0.176	0.0050	mg/L	2017-06-23	2017-06-23	
Antimony, total	< 0.00010	0.00010	mg/L	2017-06-23	2017-06-23	
Arsenic, total	< 0.00050	0.00050	mg/L	2017-06-23	2017-06-23	
Barium, total	0.0058	0.0050	mg/L	2017-06-23	2017-06-23	
Boron, total	0.004	0.004	mg/L	2017-06-23	2017-06-23	
Cadmium, total	< 0.000010	0.000010	mg/L	2017-06-23	2017-06-23	
Calcium, total	5.97	0.20	mg/L	2017-06-23	2017-06-23	
Chromium, total	< 0.00050	0.00050	mg/L	2017-06-23	2017-06-23	
Cobalt, total	< 0.00010	0.00010	mg/L	2017-06-23	2017-06-23	
Copper, total	0.00045	0.00020	mg/L	2017-06-23	2017-06-23	
Iron, total	0.013	0.010	mg/L	2017-06-23	2017-06-23	
Lead, total	< 0.00010	0.00010	mg/L	2017-06-23	2017-06-23	
Magnesium, total	1.29	0.010	mg/L	2017-06-23	2017-06-23	
Manganese, total	0.00377	0.00020	mg/L	2017-06-23	2017-06-23	
Mercury, total	< 0.00002	0.00002	mg/L	2017-06-26	2017-06-27	
Molybdenum, total	0.00039	0.00010	mg/L	2017-06-23	2017-06-23	
Nickel, total	0.00027	0.00020	mg/L	2017-06-23	2017-06-23	
Potassium, total	0.50	0.02	mg/L	2017-06-23	2017-06-23	
Selenium, total	< 0.00050	0.00050	mg/L	2017-06-23	2017-06-23	
Sodium, total	3.85	0.02	mg/L	2017-06-23	2017-06-23	
Uranium, total	0.000022	0.000020	mg/L	2017-06-23	2017-06-23	
Zinc, total	< 0.0040	0.0040	mg/L	2017-06-23	2017-06-23	

**REPORTED TO PROJECT** Black Mountain Irrigation District  
Comprehensive

**WORK ORDER REPORTED** 7061958  
2017-06-28

Analyte	Result / Recovery	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	--------------	-------	----------	----------	-------

**Sample ID: Booster #1 (7061958-01) [Water] Sampled: 2017-06-21 08:00, Continued**

**Microbiological Parameters**

Coliforms, Total	< 1	1	CFU/100 mL	N/A	2017-06-22	
E. coli	< 1	1	CFU/100 mL	N/A	2017-06-22	

**Sample ID: Well 5 (7061958-02) [Water] Sampled: 2017-06-21 08:00**

**Anions**

Chloride	11.2	0.10	mg/L	N/A	2017-06-22	
Fluoride	0.15	0.10	mg/L	N/A	2017-06-22	
Nitrate (as N)	4.67	0.010	mg/L	N/A	2017-06-22	
Nitrite (as N)	< 0.010	0.010	mg/L	N/A	2017-06-22	
Sulfate	24.4	1.0	mg/L	N/A	2017-06-22	

**General Parameters**

Alkalinity, Total (as CaCO <sub>3</sub> )	205	1.0	mg/L	N/A	2017-06-24	
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	< 1.0	1.0	mg/L	N/A	2017-06-24	
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	205	1.0	mg/L	N/A	2017-06-24	
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	< 1.0	1.0	mg/L	N/A	2017-06-24	
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	< 1.0	1.0	mg/L	N/A	2017-06-24	
Colour, True	< 5.0	5.0	CU	N/A	2017-06-23	
Conductivity (EC)	496	2.0	µS/cm	N/A	2017-06-24	
Cyanide, Total	< 0.0020	0.0020	mg/L	N/A	2017-06-27	
pH	8.01	0.01	pH units	N/A	2017-06-24	HT2
Temperature, at pH	23		°C	N/A	2017-06-24	HT2
Turbidity	< 0.10	0.10	NTU	N/A	2017-06-21	

**Calculated Parameters**

Hardness, Total (as CaCO <sub>3</sub> )	244	0.500	mg/L	N/A	N/A	
Langelier Index	0.8	-5.0	-	N/A	2017-06-28	
Solids, Total Dissolved (calc)	283	1.00	mg/L	N/A	N/A	

**Total Metals**

Aluminum, total	< 0.0050	0.0050	mg/L	2017-06-23	2017-06-23	
Antimony, total	< 0.00010	0.00010	mg/L	2017-06-23	2017-06-23	
Arsenic, total	< 0.00050	0.00050	mg/L	2017-06-23	2017-06-23	
Barium, total	0.0203	0.0050	mg/L	2017-06-23	2017-06-23	
Boron, total	0.029	0.004	mg/L	2017-06-23	2017-06-23	
Cadmium, total	< 0.000010	0.000010	mg/L	2017-06-23	2017-06-23	
Calcium, total	73.6	0.20	mg/L	2017-06-23	2017-06-23	
Chromium, total	< 0.00050	0.00050	mg/L	2017-06-23	2017-06-23	
Cobalt, total	< 0.00010	0.00010	mg/L	2017-06-23	2017-06-23	
Copper, total	0.00393	0.00020	mg/L	2017-06-23	2017-06-23	
Iron, total	< 0.010	0.010	mg/L	2017-06-23	2017-06-23	
Lead, total	0.00016	0.00010	mg/L	2017-06-23	2017-06-23	
Magnesium, total	14.7	0.010	mg/L	2017-06-23	2017-06-23	
Manganese, total	< 0.00020	0.00020	mg/L	2017-06-23	2017-06-23	
Mercury, total	< 0.00002	0.00002	mg/L	2017-06-26	2017-06-27	
Molybdenum, total	0.00179	0.00010	mg/L	2017-06-23	2017-06-23	

**REPORTED TO PROJECT** Black Mountain Irrigation District  
Comprehensive

**WORK ORDER REPORTED** 7061958  
2017-06-28

Analyte	Result / Recovery	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	--------------	-------	----------	----------	-------

**Sample ID: Well 5 (7061958-02) [Water] Sampled: 2017-06-21 08:00, Continued**

**Total Metals, Continued**

Nickel, total	0.00036	0.00020	mg/L	2017-06-23	2017-06-23	
Potassium, total	2.10	0.02	mg/L	2017-06-23	2017-06-23	
Selenium, total	0.00197	0.00050	mg/L	2017-06-23	2017-06-23	
Sodium, total	10.8	0.02	mg/L	2017-06-23	2017-06-23	
Uranium, total	0.00191	0.000020	mg/L	2017-06-23	2017-06-23	
Zinc, total	0.0076	0.0040	mg/L	2017-06-23	2017-06-23	

**Microbiological Parameters**

Coliforms, Total	< 1	1	CFU/100 mL	N/A	2017-06-22	
E. coli	< 1	1	CFU/100 mL	N/A	2017-06-22	

**Sample / Analysis Qualifiers:**

HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.